

# **Lucky Corridor Mora Line Transmission Project**

## **Non-Tariff System Impact Study**

**May 2017  
Revised November 2017**

**Main Analysis Prepared by:  
Utility System Efficiencies, Inc. (USE)**

**Under Contract with:  
Public Service Company of New Mexico**

**&**

**Gladstone Phase Shifter Sensitivity Prepared by:  
Public Service Company of New Mexico (PNM)**



## Foreword

This technical report is prepared for Lucky Corridor (Interconnection Customer) who submitted an Interconnection Application to Public Service Company of New Mexico (PNM). This study (except the Gladstone Phase Shifter Sensitivity) was performed by Utility System Efficiencies, Inc. (USE) pursuant to a consulting contract with PNM Transmission/Distribution Planning and Contracts Department.

Neither USE, PNM, TSGT, any member of USE, any cosponsor, nor any person acting on behalf of any of them:

(a) makes any warranty or representation whatsoever, express or implied, (i) with respect to the use of any information, apparatus, method, process, or similar item disclosed in this document, including merchantability and fitness for a particular purpose, or (ii) that such use does not infringe on or interfere with privately owned rights, including any party's intellectual property, or (iii) that this document is suitable to any particular user's circumstance; or

(b) assumes responsibility for any damages or other liability whatsoever (including any consequential damages, even if USE or any USE representative or PNM or any PNM representative has been advised of the possibility of such damages) resulting from your selection or use of this document or any information, apparatus, method, process, or similar item disclosed in this document.

Any correspondence concerning this document, including technical and commercial questions should be referred to:

Thomas Duane  
Manger of Transmission Planning  
Public Service Company of New Mexico  
Alvarado Square MS-0604  
Albuquerque, NM 87158  
Phone: (505) 241-4582  
Fax: (505) 241-4363

## Table of Contents

---

|                                                                     |    |
|---------------------------------------------------------------------|----|
| Executive Summary.....                                              | 1  |
| Power Transfers to the Four Corners Area .....                      | 3  |
| Introduction .....                                                  | 6  |
| Study Criteria .....                                                | 6  |
| Power Flow Criteria.....                                            | 7  |
| Transient Stability Criteria .....                                  | 7  |
| Short Circuit Criteria .....                                        | 8  |
| Power Flow Base Case Development.....                               | 8  |
| Generation Dispatch .....                                           | 9  |
| Power Flow Case Attributes.....                                     | 10 |
| List of Contingencies .....                                         | 11 |
| Power Flow Analysis Results .....                                   | 13 |
| Power Flow Results .....                                            | 13 |
| Power Flow – Voltage Performance Results.....                       | 15 |
| Short-Circuit Analysis Results.....                                 | 18 |
| Transient Stability Analysis Results.....                           | 18 |
| Transmission Interconnection Facilities.....                        | 19 |
| <br>Appendix A - Power Flow Diagrams                                |    |
| <br>Appendix B - Transient Stability Plots                          |    |
| <br>Appendix C – Generator dynamic data                             |    |
| <br>Appendix D – Short Circuit Results                              |    |
| <br>Appendix E – Historical Walsenburg – Gladstone 230 kV line flow |    |

## List of Figures

---

|                                                                        |   |
|------------------------------------------------------------------------|---|
| Figure 1 - Mora Line Model illustration .....                          | 1 |
| Figure 2 — Breaker level one-line drawing of the existing system. .... | 2 |
| Figure 3 — Breaker level one-line drawing of the proposed MLTP .....   | 3 |

## List of Tables

---

|                                                                                                               |    |
|---------------------------------------------------------------------------------------------------------------|----|
| Table 1 — Transmission Interconnection Upgrades.....                                                          | 5  |
| Table 2 — Power Flow Disturbance/Performance Criteria .....                                                   | 7  |
| Table 3 — PNM Fault Clearing Times.....                                                                       | 8  |
| Table 4 — Generation Dispatch .....                                                                           | 9  |
| Table 5 — Power Flow Case Attributes – Base Scenario .....                                                    | 10 |
| Table 6 — Power Flow Contingencies.....                                                                       | 11 |
| Table 7 — Transient Stability Contingencies .....                                                             | 12 |
| Table 8 – 2021 Heavy Winter Results .....                                                                     | 14 |
| Table 9 – 2017 Light Spring Results With Gladstone PST at 107 MW .....                                        | 14 |
| Table 10 — Light Spring Overloads with Gallegos Collector at 160 MW and Gladstone PST setting at 180 MW. .... | 15 |
| Table 11 – 2021 Heavy Winter Post-Contingency Voltage Results.....                                            | 16 |
| Table 12 – 2017 Light Spring Post-Contingency Voltage Results.....                                            | 16 |
| Table 13— Light Spring Gladstone PST 180 case .....                                                           | 17 |

Confidential: Sean Black (ID: 68709) / sblack2@ameren.com | Ameren on 2019-03-05

## Executive Summary

On August 6, 2015, Lucky Corridor, LLC. ("LCLLC") requested a non-tariff wires-to-wires interconnection of the Mora Line Transmission Project ("MLTP") to Public Service Company of New Mexico's (PNM) radial 115 kV transmission line serving the PNM Arriba distribution substation. LCLLC proposes to interconnect the MLTP at Tri-State Generation and Transmission Association's (TSGT) Gladstone and Springer 115 kV Switching Stations. The project parallels TSGT's existing 115 kV transmission line from Gladstone to Springer and will parallel portions of the existing TSGT 115 kV line from Springer to Storrie Lake.

Figure 1 below, shows the MLTP and proposed switching station additions for interconnection. The purpose of the project is to accommodate additional renewable resources in the region. Previous analysis has shown that up to 180 MW of additional generation can be accommodated with this project.





Figure 1 - Mora Line Model illustration

This analysis is limited to studying the ability to interconnect and inject power at the points of delivery to PNM's and TSGT's systems with an assumed delivery to Four Corners on an "as available" basis only using non-firm transmission capacity. Transmission service on either PNM's or TSGT's system requires a separate request for transmission service and will be analyzed in accordance with PNM's or TSGT's Open Access Transmission Tariff ("OATT"). Likewise, this study is not and does not substitute for a generation

interconnection System Impact Study. Note that Interconnection Service in and of itself does not convey Transmission Service. This study provides a non-binding cost and construction schedule estimate for all identified system reinforcements required to interconnect the MLTP.

Figure 2 is a breaker level drawing of the existing transmission system.



**Figure 2 — Breaker level one-line drawing of the existing system.**

Figure 3 represents an overlay of the proposed MLTP showing the proposed interconnection upgrades for interconnection. Due to space limitations, the existing shunt capacitor at Springer switching station will have to be moved to accommodate the MLTP. The circuit switcher that connects the capacitor today will be retired. It is assumed that when it is relocated it will be fitted with a synchronizing breaker.




Figure 3 — Breaker level one-line drawing of the proposed MLTP

## Power Transfers to the Four Corners Area

The project sponsors have expressed an interest in determining the interconnection facilities and system improvements needed to accept power at the points of interconnection to PNM's and TSGT's system and deliver up to 180 MW of power to Four Corners. Resources connected to the MLTP were offset by reducing generation beyond the Four Corners area to determine what transmission system improvements are required to deliver those resources. This analysis only determined the transmission interconnection upgrades are required for the PNM and TSGT transmission systems. The system improvements for transmission service beyond PNM's system at Four Corners will require separate requests be made with the associated transmission service providers.



The purpose of this study was to determine the system reinforcements required to safely and reliably interconnect the MLTP to the PNM and TSGT transmission systems. The final design and cost estimates of any system reinforcements required for interconnection will be undertaken in a separate facility study, should the customer decide to pursue their MLTP.

The findings of this System Impact Study are summarized as follows:

### **Steady-State Performance**

The results of the powerflow analysis show that the amount of power that can be injected from the MLTP depends on the flow scheduled on the Gladstone Phase-Shifting-Transformer (PST). Historical flows on the Walsenburg-Gladstone line have ranged up to 180 MW with typical flows ranging in the 100 MW to 150 MW range<sup>1</sup>. The forecast schedules on the Walsenburg-Gladstone line are expected to be similar to what has been observed with historical flows.

This analysis showed that the 160 MW level could be accommodated without transmission system improvements when schedule flow on the Walsenburg-Gladstone 230 kV line was at or below 135 MW. The amount of power that could be accepted from the MLTP at Gladstone decreased to 83 MW with Gladstone PST schedules at 180 MW. The reduction of the Mora generation is approximately 1 MW for each MW increase in the Gladstone PST schedule. Details of this analysis are shown on page 13.

The analysis determined that the most limiting conditions for the MLTP were due to equipment limits and voltage criteria violations that occur in the 2017 light spring case. In order to support a Project schedule of 160 MW with a Gladstone PST schedule above 135 MW, transmission system improvements will be required to address several line overloads and voltage issues around Gladstone. The violations identified in this analysis include:

- Zia – Valencia 115 kV line overload
- Gladstone – Springer 115 kV (TSGT) line overload
- Gladstone – Springer 115 kV (MLTP) line overload
- Taos – Black Lake 115 kV (TSGT) line overload
- Automatic capacitor switching at Springer and Black Lake

This analysis has only identified the likely system impacts and does not address the specific transmission system improvements needed to mitigate these overloads. This will be determined at a later date through studies addressing transmission service requests on PNM's and Tri-State's systems. Specific details can be seen on pages 15 through 17.

Power factor at Gladstone Switching Station: PNM and Tri-State will require the MLTP to maintain unity power factor at the point of interconnection at the Gladstone Switching Station. Based upon the power flow analysis performed in this study, it is expected that the MLTP will have to provide up to 30 MVar of reactive power being absorbed by the MLTP depending on the length of the line from Don Carlos (8 to 17 miles). This analysis only captures reactive compensation tied to the transmission system and does not include a specific wind collector system design at Don Carlos which will influence overall reactive compensation requirements. Ultimately the interconnection customer will have to verify that the project can meet or exceed PNM and Tri-State interconnection requirements.

---

<sup>1</sup> Historical flows on the Walsenburg – Gladstone 230 kV line pre and post PST have varied from 150-200 MW as can be seen in Appendix E

### **Transient Stability Performance**

The study results showed that the new Mora line did not cause any transient stability violations, for all single and double contingencies studied. This analysis only captured transient stability performance with an estimate of how Gallegos collector generation might perform given the plan of the MLTP. A subsequent System Impact Study will be performed when a Transmission Service Request is made which will verify acceptable system performance for the final design of the Gallegos collector system and wind turbines.

### **Short Circuit Analysis**

A short circuit study was conducted to determine if the existing circuit breakers are sufficient to accommodate the MLTP. Based on these results, the existing circuit breakers are adequate. Please See Appendix E for detailed results.

### **Conclusion**

Based on a potential generation injection level of 83 MW, the estimated costs and schedule for the MLTP interconnection upgrades are summarized below. (This estimate does not include costs for system improvements associated at higher output levels of MLTP.) PNM provided estimated costs and construction schedules for interconnection on PNM's at the Arabia substation. TSGT provided estimated costs and construction schedules for interconnection at the Springer and Gladstone stations. The Facility Study will provide a detail cost estimate and schedule. Both PNM and TSGT will develop their own Facility Study that will be incorporated into their wires-to-wires interconnection agreement with MLTP.

**Table 1 — Transmission Interconnection Upgrades**

| Transmission Interconnection Upgrades                                                                                                                                | Cost        | Construction time | Utility |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|-------------------|---------|
| Construct a new 3 breaker ring at the intersection of the Valencia – Storrie 115 kV line and Arriba Tap 115 kV transmission line.                                    | 8.25        | 18 months         | PNM     |
| Interconnect Arriba Station to MLTP via 1 115 kV breaker                                                                                                             | 1.0         | 6 months          | PNM     |
| Install new line positions, associated dead ends, 4-115kV circuit breakers, 5-115kV disconnects, CCVTs and metering to terminate MLTP at Springer Switching Station  | 2.74        | 24 months         | TSGT    |
| Install new line positions, associated dead ends, 5-115kV circuit breakers, 8-115kV disconnects, CCVTs and metering to terminate MLTP at Gladstone Switching Station | 3.16        | 24 months         | TSGT    |
| <b>Total</b>                                                                                                                                                         | <b>15.2</b> | <b>24 months</b>  |         |



## Introduction

This non-tariff wires-to-wires interconnection study reviews the MLTP as requested by the customer. Previous analysis<sup>2</sup> identified the ability to accommodate up to 180 MW of MLTP power at Gladstone. The purpose of the analysis is to evaluate the impact and identify the facilities required to interconnect the MLTP.

This analysis is limited to studying the ability to interconnect and inject power at the points of delivery to PNM's and TSGT's systems with an assumed delivery to Four Corners on an "as available" basis only using non-firm transmission capacity. Transmission service on either PNM's or TSGT's system requires a separate request for transmission service and will be analyzed in accordance with PNM's or TSGT's Open Access Transmission Tariff ("OATT"). Likewise, this study is not and does not substitute for a generation interconnection System Impact Study. Note that Interconnection Service in and of itself does not convey Transmission Service. This study provides a non-binding cost and construction schedule estimate for all identified system reinforcements required to interconnect the MLTP.

This report details the results for the SIS which determines the physical and electrical impacts to PNM's and TSGT's transmission system from the MLTP. It then identifies the required interconnection upgrades and Customer obligations to accommodate the interconnection request. The results of this study are based on power flow (equipment and voltage performance), transient stability (dynamic simulation), and short circuit analysis.

This SIS also provides a non-binding cost and construction schedule estimate for all identified system reinforcements required for interconnection of MLTP.

## Study Criteria

A system reliability evaluation consists of power flow analysis for identifying equipment overloads or voltages outside criteria (too high or low) under normal and contingency conditions. Transient stability analysis is performed to ensure all machines remain in synchronism, all voltage swings are damped within acceptable limits, and all oscillations show positive damping within 30-seconds after the start of the studied event. A short circuit analysis is performed to ensure all fault currents remain within acceptable circuit breaker and switch capabilities. Each evaluation is conducted for credible contingencies that the system might sustain, such as the loss of a single or double circuit line, a transformer, a generator or a combination of these facilities. This study was completed in accordance to NERC Standard FAC-002-2.

Performance of the transmission system is measured against the following planning criteria: the Western Electricity Coordinating Council (WECC) Reliability Criteria, and the North American Electric Reliability Council (NERC) Planning Standards. If system reliability problems resulting from the interconnection of a project are discovered, the study will identify the system facilities or operational measure that will be necessary to mitigate reliability criteria violations. Addition of these new facilities would maintain the reliability to the transmission network.

This SIS investigates whether the MLTP results in:

---

<sup>2</sup> Lucky Corridor, LLC Mora Line Transmission Project report. June 30, 2015

- Equipment overloads on transmission lines, transformers, series compensation or other devices
- Voltage criteria violations
- All machines do not remain synchronized to the transmission system
- Voltage swings exceed acceptable limits
- Positive damping does not occur within 30 seconds
- Fault duty increases that result in short circuit current that exceeds the interrupt rating of circuit breakers and switches

## Power Flow Criteria

All power flow analysis is conducted with version 19.1\_01 of General Electric's PSLF/PSDS/SCSC software. Traditional power flow analysis is used to evaluate equipment and voltage performance of the system under Category P0 (all elements in service), Category P1 (N-1) and Category P4 and P7 (N-2) conditions.<sup>3</sup>

The power flow performance criteria utilized to assess the impact of the MLTP throughout the SIS are shown in the table below. The criteria are WECC/NERC performance requirements<sup>4</sup> with applicable additions and/or exceptions for the New Mexico transmission system<sup>5</sup>.

**Table 2 — Power Flow Disturbance/Performance Criteria**

| AREA                            | CONDITION        | LOADING LIMIT      | VOLTAGE RANGE (p.u) | VOLTAGE DEVIATION | APPLICATION    |
|---------------------------------|------------------|--------------------|---------------------|-------------------|----------------|
| EPEC<br>(Area 11)               | Normal ALIS (P0) | < Normal Rating    | 0.95 - 1.05         | NA                | BES facilities |
|                                 | P1               | < Emergency Rating | 0.90 - 1.10         | 8% <sup>5</sup>   | BES facilities |
|                                 | P2-P7            | < Emergency Rating | 0.90 - 1.10         | NA                | BES facilities |
| PNM<br>(Area 10)                | Normal ALIS (P0) | < Normal Rating    | 0.95 - 1.05         | NA                | BES facilities |
|                                 | P1               | < Emergency Rating | 0.90 - 1.10         | 8%                | BES facilities |
|                                 | P2-P7            | < Emergency Rating | 0.90 - 1.10         | NA                | BES facilities |
| Tri- State<br>Zone<br>(120-123) | Normal ALIS (P0) | < Normal Rating    | 0.95 - 1.05         | NA                | BES facilities |
|                                 | P1               | < Emergency Rating | 0.90 - 1.10         | 8%                | BES facilities |
|                                 | P2-P7            | < Emergency Rating | 0.90 - 1.10         | NA                | BES facilities |

1) Taiban Mesa 345, Guadalupe 345 kV and Jicarilla 345 kV voltages 0.950 and 1.10 pu under normal and contingency conditions

2) PNM will monitor 46 & 69 kV facilities

3) El Paso will monitor 69 kV facilities

4) Greenlee 345 kV is a 5% voltage Drop

5) Per 10/5/2016 - email - 7% voltage drop will be use for 345 kV buses

6) Per 10/5/2016 - email - EPE will modify its criteria in the 2017 FERC 715 filing

- All equipment loadings must be below their normal ratings under normal conditions.
- All line loadings must be below their emergency ratings for both single and double contingencies. All transformers and equipment with emergency rating should be below their emergency rating.

## Transient Stability Criteria

The NERC/WECC transient stability performance requirements for transmission contingencies are as follows:

<sup>3</sup> For TPL-004-0 see NERC website <http://www.nerc.com>

<sup>4</sup> For TPL-001-WECC-1-CR, TPL-002-WECC-1-CR, TPL-003-WECC-1-CR, TPL-004-WECC-1-CR see <http://www.wecc.biz/Standards/WECC%20Criteria/Forms/AllItems.aspx>

<sup>5</sup> For PNM exceptions to WECC criteria see [http://www.oatioasis.com/PNM/PNMdocs/PNM\\_Study\\_Criteria\\_and\\_Guidelines\\_03-04-08.pdf](http://www.oatioasis.com/PNM/PNMdocs/PNM_Study_Criteria_and_Guidelines_03-04-08.pdf)

- All machines will remain in synchronism.
- All voltage swings are well damped.
- Following fault clearing, the voltage shall recover to 80% of the pre-contingency voltage within 20 seconds of the initiating event for all P1 through P7 events, for each applicable BES bus serving load.
- Following fault clearing and voltage recovery above 80%, voltage at each applicable BES bus serving load shall neither dip below 70% of pre-contingency voltage for more than 30 cycles nor remain below 80% of pre-contingency voltage for more than two seconds, for all P1 through P7 events.
- All frequency dips are well damped.

Fault clearing times used in this SIS are shown in Table 3.

**Table 3 — PNM Fault Clearing Times**

| Categories   | Fault Type               | Voltage (kV) | Clearing Time (near far end breakers)                                                                                     |
|--------------|--------------------------|--------------|---------------------------------------------------------------------------------------------------------------------------|
| P1,P3,P6, P7 | 3 Phase Normally Cleared | 345          | 4–4 Cycles                                                                                                                |
|              |                          | 230          | 4–4 Cycles                                                                                                                |
|              |                          | 115          | 4–4 Cycles                                                                                                                |
| Categories   | Fault Type               | Voltage (kV) | Clearing Time (normally opened breaker both near and far end — breaker opened due to stuck breaker both near and far end) |
| P2,P4,P5,P7  | 1 Phase Stuck Breaker    | 345          | 4-12 Cycles                                                                                                               |
|              |                          | 230          |                                                                                                                           |
|              |                          | 115          | 4-15 Cycles                                                                                                               |

## Short Circuit Criteria

Breakers in excess of 92% are flagged for determination as to when the breaker should be considered for upgrading. Generally based on age and maintenance related issues those in excess 95% are to be scheduled for upgrade.

## Power Flow Base Case Development

The following approved WECC cases were used to evaluate the proposed transmission project. A 2020 Heavy Summer case (2020HS2a), a 2021 Heavy Winter case (2021HW1a) and 2017 Light Spring case (2017 LSP) were used to model the base system as well as the post MLTP.

| Case                  | Projects                                        |
|-----------------------|-------------------------------------------------|
| 2020HS2A              | Base system                                     |
| 2020HS2A-post project | Base system with MLTP and associated generation |
| 2021HW1A              | Base system                                     |
| 2021HW1A-post project | Base system with MLTP and associated generation |



|                      |                                                 |
|----------------------|-------------------------------------------------|
| 2017LSP              | Base System                                     |
| 2017LSP-post project | Base system with MLTP and associated generation |

Details of the generation dispatch and resulting path/transmission element flows, and bus voltages of interest are discussed in the "Power Flow Case Attributes" section of this report.

## Generation Dispatch

Generation dispatch (before the addition of MLTP) of existing and planned facilities for each case used in the analysis is itemized in the table below. It was assumed the associated generation for the MLTP would displace generation in California for modeling purposes.

**Table 4 — Generation Dispatch**

| Unit                                     | Nameplate Rating | 2020 HS output | 2020-2021 HW output | 2017 LS output |
|------------------------------------------|------------------|----------------|---------------------|----------------|
| <b>Coal</b>                              |                  |                |                     |                |
| San Juan Unit 1                          | 370              | 360            | 360                 | 232.9          |
| San Juan Unit 2 (retired)                | 0                | 0              | 0                   | 0              |
| San Juan Unit 3 (retired)                | 0                | 0              | 0                   | 0              |
| San Juan Unit 4 (Area Swing)             | 544              | 510            | 530                 | 485/500        |
| Four Corners Unit 1 (retired)            | 0                | 0              | 0                   | 0              |
| Four Corners Unit 2 (retired)            | 0                | 0              | 0                   | 0              |
| Four Corners Unit 3 (retired)            | 0                | 0              | 0                   | 0              |
| Escalante Generating Station             | 265              | 223            | 234                 | 150            |
| Comanche 1 & 2                           | 725              | 671            | 689                 | 490            |
| Comanche 3                               | 805              | 780            | 750                 | 450            |
| <b>Natural Gas/Oil</b>                   |                  |                |                     |                |
| Reeves 1 (Natural Gas)                   | 43               | 0              | 0                   | 0              |
| Reeves 2 (Natural Gas)                   | 44               | 0              | 0                   | 0              |
| Reeves 3 (Natural Gas)                   | 66               | 25             | 25                  | 0              |
| Rio Bravo (Natural Gas/Oil)              | 132              | 0              | 0                   | 0              |
| Luna Energy Facility (Natural Gas)       | 570              | 520            | 520                 | 330            |
| Lordsburg (Natural Gas)                  | 80               | 0              | 0                   | 0              |
| Afton (Natural Gas)                      | 235              | 235            | 0                   | 0              |
| Valencia Energy Facility (Natural Gas)   | 173              | 117            | 0                   | 0              |
| La Luz #1 (Natural Gas)                  | 42.3             | 0              | 0                   | 0              |
| San Juan Gas Plant                       | 87               | 81             | 81                  | 81             |
| Pyramid Generating Station (Natural Gas) | 160              | 104            | 25                  | 61             |
| Black Hills CT (BACULITE)                | 400              | 375            | 250                 | 183            |
| <b>Wind Resources</b>                    |                  |                |                     |                |
| Taiban Mesa Wind Project                 | 200              | 10             | 100                 | 100            |
| Aragonne Mesa Wind Project               | 90               | 69             | 69.0                | 69             |
| Red Mesa Wind Project                    | 102              | 5              | 51                  | 51             |
| High Lonesome Mesa Wind Project          | 100              | 78             | 78                  | 78             |
| <b>Solar Resources</b>                   |                  |                |                     |                |
| Ambrose Solar Project                    | 9                | 9              | 0                   | 0              |
| Reeves Solar Project                     | 3                | 2              | 0                   | 0              |
| Los Lunas Solar Project                  | 7                | 5              | 0                   | 0              |
| Manzano Solar Project                    | 8.9              | 6              | 0                   | 0              |
| Marquez Solar Project                    | 10               | 7              | 0                   | 0              |
| Meadow Lake Solar                        | 9                | 6              | 0                   | 0              |
| Prosperity Energy Storage (Studio)       | .5               | .5             | 0                   | 0              |
| Enchanted Mesa                           | 9.8              | 6              | 0                   | 0              |
| VIA                                      | 10               | 7              | 0                   | 0              |
| Huning Solar                             | 10               | 7              | 0                   | 0              |
| Las Vegas Solar                          | 5.0              | 5              | 0                   | 0              |
| Walsh North                              | 10               | 7              | 0                   | 0              |

|                 |      |      |   |   |
|-----------------|------|------|---|---|
| South Valley    | 9.5  | 6    | 0 | 0 |
| Santolina Solar | 11   | 7    | 0 | 0 |
| Santa Fe Solar  | 9.75 | 9.75 | 0 | 0 |
| Cook Solar      | 5    | 5    | 0 | 0 |
| Cimaron Solar   | 30   | 10.3 | 0 | 0 |
| COMANCHE Solar  | 120  | 78   | 0 | 0 |

## Power Flow Case Attributes

Table 5 provides an overview of the power flow cases after loading the project and the generation pattern into the study cases.

**Table 5 — Power Flow Case Attributes – Base Scenario**

| Unit                         | 2020 HS (MW) |      |                     | 2020-2021 HW (MW) |      |                     | 2017 LSP MW |      |                     |
|------------------------------|--------------|------|---------------------|-------------------|------|---------------------|-------------|------|---------------------|
|                              | Pre          | Post | Sens:<br>PST<br>180 | Pre               | Post | Sens:<br>PST<br>180 | Pre         | Post | Sens:<br>PST<br>180 |
| Path 47: Southern New Mexico | 76           | 76   | 76                  | 365               | 366  | 366                 | 428         | 429  | 429                 |
| Path 48: Northern New Mexico | 1818         | 1640 | 1692                | 1723              | 1011 | 1614                | 349         | 211  | 257                 |
| Blackwater Converter         | 0            | 0    | 0                   | 0                 | 0    | 0                   | 0           | 0    | 0                   |
| Arroyo Phase-Shifter         | 11           | 11   | 11                  | 51                | 46   | 46                  | 48          | 48   | 48                  |
| Walsenburg-Gladstone line    | 132          | 132  | 180                 | 135               | 133  | 180                 | 107         | 107  | 180                 |
| Don Carlos Generation        | N/A          | 160  | 115                 | N/A               | 160  | 115                 | N/A         | 160  | 83                  |

Several updates were made to all of the WECC seed cases:

- Add TSGT's planned 30 MVAR (2 x 15) shunt capacitors at Gladstone 115 kV.
- Modify the Gladstone PST and Arroyo PST transformer type in order to control/hold the flow to the current level for each case.
- Removed the San Juan Project which included:
  - Shiprock – Black Glade 230 kV line
  - Black Glade – Black Glade 230 PST
  - Black Glade – Coyote G 230 kV line
  - Coyote G – Iron Horse 230 kV line
  - Glade Tap – Black Glade S 115 kV line
  - Black Glade S – Black Glade W 115 kV line
  - Black Glade W - Black Glade WP 115 PST
  - Black Glade WP – Black Glade N 115 kV line
  - Black Glade N – El Paso Tap 115 kV line
- Update the following transformers connected to the San Juan 345 kV bus to a three-winding model:
  - 345/69 kV transformer
  - 345/230 kV transformer
- Update the Rio Puerco SVC model based on final design.
- Add Jicarilla shunt reactor
- Update the New San Juan gas generation

- Add Cabezón 345 kV and update topology
- Add Torreon 115 kV and update topology
- Open San Ysidro – Algodones 115 kV

In addition, the Los Alamos load (zone 133) was reduced in the 2020 HS and the 2021 HW cases.

- HS: Reduce Los Alamos load from 132.6 MW to 104 MW
- HW: Reduce Los Alamos load from 126.4 MW to 104 MW

## List of Contingencies

The contingencies evaluated for power flow (equipment & voltage) in this SIS are listed below.

**Table 6 — Power Flow Contingencies**

| NO.                       | CATEGORY | CONTINGENCY DESCRIPTION                                                     |
|---------------------------|----------|-----------------------------------------------------------------------------|
| Category P0 Contingencies |          |                                                                             |
| 0                         | P0       | All-lines-in service                                                        |
| Category P1 Contingencies |          |                                                                             |
| 1                         | P1       | Ojo-Taos 345 kV Line                                                        |
| 2                         | P1       | San Juan-Jicarilla 345 kV                                                   |
| 3                         | P1       | Jicarilla-Ojo 345 kV                                                        |
| 4                         | P1       | San Juan-McKinley 345 kV Line 1                                             |
| 5                         | P1       | San Juan-McKinley 345 kV Line 2                                             |
| 6                         | P1       | San Juan-Shiprock 345 kV Line                                               |
| 7                         | P1       | Cabezón -Rio Puerco 345 kV Line                                             |
| 8                         | P1       | San Juan-Hesperus 345 kV Line                                               |
| 9                         | P1       | San Juan-Four Corners 345 kV Line                                           |
| 10                        | P1       | Four Corners-Rio Puerco 345 kV Line                                         |
| 11                        | P1       | Rio Puerco-West Mesa 345 kV Line                                            |
| 12                        | P1       | BA-Rio Puerco 345 kV Line 1                                                 |
| 13                        | P1       | BA-Norton 345 kV Line                                                       |
| 14                        | P1       | BA-Guadalupe 345 kV Line                                                    |
| 15                        | P1       | West Mesa-Sandia 345 kV Line                                                |
| 16                        | P1       | Norton 345/115 kV Transformer                                               |
| 17                        | P1       | Rio Puerco 345/115 kV Transformer                                           |
| 18                        | P1       | BA 345/115 kV Transformer                                                   |
| 19                        | P1       | San Juan 345/230 kV Transformer                                             |
| 20                        | P1       | West Mesa 345/115 kV Transformer 1                                          |
| 21                        | P1       | Ojo 345/115 kV Transformer                                                  |
| 22                        | P1       | Taos 345/115 kV Transformer 1                                               |
| 23                        | P1       | Gladstone-Walsenburg 230 kV Line                                            |
| 24                        | P1       | Comanche-Walsenburg 230 kV Line, transfer trips Walsenburg-Gladstone 230 kV |
| 25                        | P1       | West Mesa-Ambrosia 230 kV Line                                              |
| 26                        | P1       | Gladstone 230 kV PST                                                        |
| 27                        | P1       | Gladstone 230/115 kV Transformer 1                                          |
| 28                        | P1       | Walsenburg 230/115 kV Transformer T2                                        |
| 29                        | P1       | West Mesa 230/115 kV Transformer 1                                          |
| 30                        | P1       | Bison-Cimarron 115 kV Line                                                  |



| NO.                            | CATEGORY | CONTINGENCY DESCRIPTION                                                                |
|--------------------------------|----------|----------------------------------------------------------------------------------------|
| 31                             | P1       | Taos-Springer 115 kV Line                                                              |
| 32                             | P1       | Clapham-Rosebud 115 kV Line                                                            |
| 33                             | P1       | Gladstone-Clapham 115 kV Line                                                          |
| 34                             | P1       | Gladstone-Hessbdw 115 kV Line                                                          |
| 35                             | P1       | Taos-Hernandez 115 kV Line                                                             |
| 36                             | P1       | Springer-Storrie Lake 115 kV Line                                                      |
| 37                             | P1       | Springer-Bison 115 kV Line                                                             |
| 38                             | P1       | Gladstone-Springer 115 kV Line 1                                                       |
| 39                             | P1       | Gladstone-Springer 115 kV Line 3 (PROJECT ELEMENT)                                     |
| 40                             | P1       | York Canyon-Bison 115 kV Line                                                          |
| 41                             | P1       | Storrie Lake-Valencia-Arriba 115 kV Line (3-term outage)                               |
| 42                             | P1       | Springer - Arriba -Gal -Arriba Tap 115 kV Line (Post-MLTP – New breaker at Arriba Tap) |
| 43                             | P1       | Zia-Valencia 115 kV line (Zia-Eldorado-Colinas-Rowe Tap-Valencia)                      |
| 44                             | P1       | Norton-Hernandez 115 kV Line                                                           |
| 45                             | P1       | Ojo-Hernandez 115 kV Line                                                              |
| 46                             | P1       | Norton-Zia 115 kV line (NS)                                                            |
| 47                             | P1       | Norton-Zia-Algodones 3 terminal 115 kV line                                            |
| 48                             | P1       | Zia-BA 115 kV line                                                                     |
| 49                             | P1       | Bluewater-Ambrosia 115 kV line                                                         |
| 50                             | P1       | Zia1-Zia2 115 kV line                                                                  |
| 51                             | P1       | Norton-ETA 115 kV line                                                                 |
| 52                             | P1       | BA-STA Station 115 kV line                                                             |
| 53                             | P1       | Clapham 115/69 kV Transformer                                                          |
| 54                             | P1       | Gallegos Collector Generator (Post-MLTP)                                               |
| 55                             | P1       | Gallegos Collector-Gladstone 115 kV Line (PROJECT ELEMENT)                             |
| 56                             | P1       | Comanche – Boone 230 kV (Gladstone PST Sensitivity)                                    |
| 57                             | P1       | Comanche - CF&IFURN 230 kV (Gladstone PST Sensitivity)                                 |
| 58                             | P1       | Comanche – MidwayPS 230 kV (Gladstone PST Sensitivity)                                 |
| 59                             | P1       | Daniel Peak – Comanche 345 kV (Gladstone PST Sensitivity)                              |
| 60                             | P1       | Comanche 345/230 Transformer (Gladstone PST Sensitivity)                               |
| 61                             | P1       | Comanche 230/155 Transformer (Gladstone PST Sensitivity)                               |
| 62                             | P1       | Comanche Solar (Gladstone PST Sensitivity)                                             |
| 63                             | P1       | Comanche Unit 1 (Gladstone PST Sensitivity)                                            |
| 64                             | P1       | Comanche Unit 2 (Gladstone PST Sensitivity)                                            |
| Category P4 & P7 Contingencies |          |                                                                                        |
| 65                             | P4       | Rio Puerco - BA 1&2 345 kV lines                                                       |
| 66                             | P4       | San Juan –Jicarilla & Jicarilla – Ojo 345 kV lines                                     |
| 67                             | P7       | Springer-Gladstone #1 & #3 115 kV lines (Post-MLTP)                                    |
| 68                             | P7       | Rio Puerco-West Mesa #1 & #2 345 kV lines                                              |

The contingencies evaluated for transient stability in this SIS are listed below.

**Table 7 — Transient Stability Contingencies**

| NO.                       | CATEGORY | CONTINGENCY DESCRIPTION | CLEARING TIME (CYCLES) |
|---------------------------|----------|-------------------------|------------------------|
| Category P0 Contingencies |          |                         |                        |



| NO.                            | CATEGORY | CONTINGENCY DESCRIPTION                  |                                                                               | CLEARING TIME (CYCLES) |
|--------------------------------|----------|------------------------------------------|-------------------------------------------------------------------------------|------------------------|
| 0                              | P0       | No Disturbance run                       |                                                                               | n/a                    |
| Category P1 Contingencies      |          |                                          |                                                                               |                        |
| 1                              | P1       | West Mesa – Arroyo 345 kV                | 3-phase fault near WEST MESA 345 kV                                           | 4                      |
| 2                              | P1       | Cabazon –Rio Puerco 345 kV               | 3-phase fault near RIO PUERCO 345 kV                                          | 4                      |
| 3                              | P1       | San Juan – Jicarilla 345 kV              | 3-phase fault SAN JUAN 115 kV                                                 | 4                      |
| 4                              | P1       | Gladstone - Springer 115 kV #1           | 3-phase fault near GLADSTONE 115 kV                                           | 4                      |
| 5                              | P1       | BA – Norton 345 kV (WB)                  | 3-phase fault near BA 345 kV                                                  | 4                      |
| 6                              | P1       | Walsenburg – Gladstone 230 kV            | 3-phase fault near GLADSTONE 230 kV                                           | 4                      |
| 7                              | P1       | Valencia – Zia 115 kV                    | 3-phase fault near VALENCIA 115 kV                                            | 4                      |
| 8                              | P1       | Taos - Springer 115 kV                   | 3-phase fault near TAOS 115 kV                                                | 4                      |
| Category P4 & P7 Contingencies |          |                                          |                                                                               |                        |
| 9                              | P4       | BA – Rio Puerco 345 kV (two circuits)    | 3-phase fault near RIO PUERCO 345 kV<br>Delayed clearing of line #2.          | 4, 12                  |
| 10                             | P4       | San Juan-Jicarilla & Jicarilla-Ojo       | 3-phase fault near JICARILLA 115 kV<br>Delayed clearing of Jicarilla-Ojo line | 4, 12                  |
| 11                             | P7       | Springer – Gladstone #1 & #3 (post-MLTP) | 3-phase fault near GLADSTONE 115 kV                                           | 4                      |

## Power Flow Analysis Results

The study modeled the interconnection of the MLTP to PNM's radial 115 kV transmission line serving the PNM Arriba distribution substation, with additional 115 kV interconnections at TSGT's Gladstone and Springer 115 kV Switching Stations. A wind generator connected to MLTP at Don Carlos was modeled with up to 180 MW of generation dispatched in order to analyze the potential impacts of the MLTP. The line to Don Carlos was modeled using 17 miles distance but has been changed to 8 miles and this change will have no material impact to the study results.

## Power Flow Results

Sixty eight (68) outages were simulated for each case modeling the 2020 Heavy Summer, 2021 Heavy Winter, and 2017 Light Spring timeframes. The post-project cases included the MLTP and up to 180 MW of generation at the Gallegos Collector for initial analysis.

## Heavy Summer Analysis

Results using the 2020 Heavy summer cases did not identify performance criteria violations at a full 180 MW Gallegos Collector output for Gladstone PST schedules of 132 MW or less in a north to south direction.

## Heavy Winter Analysis

Review of the thermal results identified one Gallegos Collector triggered overload at 180 MW of generation. Reducing the generation to 160 MW eliminated the overload. These results are tabulated in Table 8.

**Table 8 – 2021 Heavy Winter Results**

| 2021 HW |                                       |                                |     |                |                |
|---------|---------------------------------------|--------------------------------|-----|----------------|----------------|
| #       | Branch/Element                        | Contingency Description        | Pre | Post<br>160 MW | Post<br>180 MW |
| 1       | Gladstone-Springer 115 kV (TSGT) Line | Gladstone-Springer 115 kV MLTP | n/a | 93.7           | 103.2          |

## Light Spring Analysis

Review of the power flow results identified six new overloads with the Gallegos Collector associated generation at 180 MW and the Gladstone PST schedule at 107 MW. Reducing the generation to 160 MW eliminated the overloads with a Gladstone PST schedule set to a 107 MW north to south schedule. These results are tabulated in Table 8.

**Table 9 – 2017 Light Spring Results With Gladstone PST at 107 MW**

| 2017 Light Spring |                                  |                                       |     |                |                |
|-------------------|----------------------------------|---------------------------------------|-----|----------------|----------------|
| #                 | Branch/Element                   | Contingency Description               | Pre | Post<br>160 MW | Post<br>180 MW |
| 1                 | Gladstone-Springer 115 kV (TSGT) | Gladstone-Springer 115 kV Line (MLTP) | n/a | 94.1           | 104.4          |
| 2                 | Arriba Tap – Valencia 115 kV     | Taos – Springer 115 kV Line           | 5.2 | 99.4           | 110.8          |
| 3                 | Valencia – Rowe Tap 115 kV       |                                       | 4.0 | 98.3           | 109.6          |
| 4                 | Rowe Tap – Colinas 115 kV        |                                       | 2.0 | 95.2           | 106.5          |
| 5                 | Colinas – Eldorado Tap 115kV     |                                       | 2.1 | 93.6           | 104.9          |
| 6                 | Eldorado Tap – Zia 115 kV        |                                       | 2.7 | 92.9           | 104.2          |

## Sensitivity: Maximum Gladstone PST Schedule

Additional analysis for the summer, winter and light spring conditions was performed with the Gladstone PST at a 180 MW north to south schedule. Results show that the amount of power injected by the project needs to be reduced by approximately 1 MW for each 1 MW increase in the Gladstone PST schedule without system improvements to accommodate the higher flow levels. The most limiting conditions occur during the light spring season with the MLTP generation limited to 83 MW at a Gladstone PST flow of 180 MW. Table 10 shows MLTP caused overloads with the MLTP generation output at 160 MW and a Gladstone PST flow of 180 MW in the light spring case. The analysis is an indication of system impacts which will be explored further along with mitigations when Transmission Service Request related studies are performed.

**Table 10 — Light Spring Overloads with Gallegos Collector at 160 MW and Gladstone PST setting at 180 MW.**

| # | Branch/Element                   | Contingency Description          | Post – MLTP<br>160 MW<br>Output |
|---|----------------------------------|----------------------------------|---------------------------------|
| 1 | Arriba Tap – Valencia 115 kV     | Taos – Springer 115 kV Line      | 145.8                           |
| 2 | Valencia – Rowe Tap 115 kV       |                                  | 144.6                           |
| 3 | Colinas – Rowe Tap 115 kV        |                                  | 141.5                           |
| 4 | Eldorado Tap – Colinas 115 kV    |                                  | 139.8                           |
| 5 | Zia – Eldorado Tap 115 kV        |                                  | 139.1                           |
| 6 | Gladstone-Springer 115 kV (TSGT) | Gladstone-Springer 115 kV (MLTP) | 132.5                           |
| 7 | Gladstone-Springer 115 kV (MLTP) | Gladstone-Springer 115 kV (TSGT) | 103.6                           |
| 8 | Black Lake – Cruzalta Tap        | Line Valencia-Zia 115 kV         | 101.3                           |
| 9 | Taos – Cruzalta Tap              |                                  | 100.1                           |

#### Power Flow Summary:

Based on the above findings, the MLTP could accommodate up to 83 MW of Gallegos Collector injections without additional system upgrades for a 180 MW Gladstone PST flow<sup>6</sup> in light loading conditions. The reduction on the MLTP generation will be approximately a 1 for 1 ratio for the increase of the Gladstone PST flow. These upgrades will be addressed when specific Transmission Service Requests are made to deliver Gallegos Collector generation.

#### Power Flow – Voltage Performance Results

The voltage analysis focused on PNM and TSGT in Areas 10 and 70, and on voltages 46 kV and above.

#### Heavy Summer Analysis

Results showed no MLTP-triggered voltage violations for the Heavy Summer case with 160 MW of generation at higher Gladstone PST flow of 132 MW.

#### Heavy Winter Analysis

The 2021 HW cases were adjusted to incorporate a 1.035 voltage set point at the Black Lake 115 kV bus, affecting the operation of the Black Lake capacitors. (The 2017 LSP case and the 2020 HS case had the Black Lake voltage set point at 1.038 and 1.035 respectively, whereas the 2021 HW seed case had a set point of 1.025. Increasing the HW set point to 1.035 brought it in line with the other two cases and the anticipated operation of the TSGT system.)

Results show MLTP triggered high voltages at the limit of the criteria for the P7 of Springer-Gladstone Circuits (TSGT and MLTP lines). Mitigation would be to open capacitors at Springer post contingency.

<sup>6</sup> Report: Methodology for Determining System Operating Limits of the Gladstone Phase Shifting Transformer

**Table 11 – 2021 Heavy Winter Post-Contingency Voltage Results**

| 2021 Heavy Winter, one TSGT Gladstone-Springer line |          |     |      |                                                                           | PU Voltage   |             | Mitigation                |
|-----------------------------------------------------|----------|-----|------|---------------------------------------------------------------------------|--------------|-------------|---------------------------|
| #                                                   | Bus      | kV  | Area | Contingency                                                               | WECC – CRT-3 | Post 160 MW |                           |
| 1                                                   | ARRIBA   | 115 | 10   | P7: Springer – Gladstone TSGT & MLTP 115 kV lines (Post-MLTP Contingency) | 1.1          | 1.09        | Turn off Springer SVD/cap |
| 2                                                   | ARRIBA_T | 115 | 10   |                                                                           | 1.1          | 1.09        |                           |
| 3                                                   | VALENCIA | 115 | 10   |                                                                           | 1.1          | 1.09        |                           |
| 4                                                   | GALLINAT | 115 | 10   |                                                                           | 1.1          | 1.09        |                           |
| 5                                                   | SPRINGER | 69  | 10   |                                                                           | 1.1          | 1.12        |                           |
| 6                                                   | YORKCANY | 69  | 10   |                                                                           | 1.1          | 1.12        |                           |

The above findings were based on Mora generation of 160 MW at a Gladstone PST schedule of 135 MW north to south.

### Light Spring Analysis

The Black Lake and Springer SVDs are both on pre-contingency in the post-MLTP case.

Results showed high voltage violations in the post-MLTP case for the loss of both Springer-Gladstone Circuits (TSGT and MLTP lines). These voltages can be mitigated post-contingency by turning off the Springer capacitor and allowing the Springer 115/69 kV transformer taps to operate. Alternately, if the pre-contingency voltage at Springer is lowered to ~ 1.0 pu (turning off the Springer shunt capacitor) and the WECC-CRT-3 voltage limits are employed, the only potential voltage issues are at the Springer 69 kV bus and the York canyon 69 kV buses which could be adjusted with transformer taps, or by turning off the Black Lake SVD. If faster post-contingency operation is required, the MLTP could install a fast acting reactive source (~ 13 MVAR) at Springer 115 kV or replace/upgrade the existing Springer SVD with a faster-acting device.

**Table 12 – 2017 Light Spring Post-Contingency Voltage Results**

| 2017 Light Spring, one TSGT Gladstone-Springer line |          |     |      |                                                                           |              |             |                                                                                        |
|-----------------------------------------------------|----------|-----|------|---------------------------------------------------------------------------|--------------|-------------|----------------------------------------------------------------------------------------|
| #                                                   | Bus      | kV  | Area | Contingency                                                               | WECC – CRT-3 | Post 160 MW | Mitigation                                                                             |
| 1                                                   | ARRIBA   | 115 | 10   | P7: Springer – Gladstone TSGT & MLTP 115 kV lines (Post-MLTP Contingency) | 1.1          | 1.11        | Turn off Springer SVD/cap and allow the Springer 115/69 kV transformer taps to operate |
| 2                                                   | ARRIBA_T | 115 | 10   |                                                                           | 1.1          | 1.11        |                                                                                        |
| 3                                                   | VALENCIA | 115 | 10   |                                                                           | 1.1          | 1.11        |                                                                                        |
| 4                                                   | GALLINAT | 115 | 10   |                                                                           | 1.1          | 1.11        |                                                                                        |
| 5                                                   | BLACKLAK | 69  | 10   |                                                                           |              | 1.10        |                                                                                        |
| 6                                                   | BLACKLAK | 115 | 10   |                                                                           | 1.1          | 1.10        |                                                                                        |
| 7                                                   | SPRINGER | 69  | 10   |                                                                           |              | 1.15        |                                                                                        |
| 8                                                   | SPRINGER | 115 | 10   |                                                                           | 1.1          | 1.13        |                                                                                        |
| 9                                                   | STORRIE  | 115 | 10   |                                                                           | 1.1          | 1.11        |                                                                                        |
| 10                                                  | YORKCANY | 69  | 10   |                                                                           |              | 1.14        |                                                                                        |
| 11                                                  | YORKCANY | 115 | 10   |                                                                           | 1.1          | 1.12        |                                                                                        |
| 12                                                  | RAINSVIL | 115 | 10   |                                                                           | 1.1          | 1.12        |                                                                                        |

|    |           |     |    |     |      |
|----|-----------|-----|----|-----|------|
| 13 | RAINSVILX | 115 | 10 | 1.1 | 1.12 |
| 14 | BISON     | 115 | 10 | 1.1 | 1.12 |
| 15 | CIMARRON  | 115 | 10 | 1.1 | 1.12 |

### Sensitivity: Gladstone Phase Shifting transformer at 180 MW

The voltage performance with the Gladstone PST at 180 MW was the worst in the light spring case as seen below in Table 13. The required mitigation is automatic capacitor tripping post contingency at Springer and Black Lake. Gallegos Collector generation was dispatched at 160 MW for this analysis. This result was not verified in Stability and is only an indication of voltage remediation that will have to be revisited upon a Transmission Service Request (System Impact Study) analysis where the actual plan of service will be studied.

Table 13— Light Spring Gladstone PST 180 case

| 2017 Light Spring |           |     |      |                                                                     |              |             |                                                                                                                |
|-------------------|-----------|-----|------|---------------------------------------------------------------------|--------------|-------------|----------------------------------------------------------------------------------------------------------------|
| #                 | Bus       | kV  | Area | Contingency                                                         | WECC – CRT-3 | Post 160 MW | Mitigation                                                                                                     |
| 1                 | ARRIBA    | 115 | 10   | P7: Springer – Gladstone TSGT & MLTP 115 kV (Post-MLTP Contingency) | 1.1          | 1.10        | Automatically trip Springer and Black Lake capacitors allow the Springer 115/69 kV transformer taps to operate |
| 2                 | ARRIBA_T  | 115 | 10   |                                                                     | 1.1          | 1.10        |                                                                                                                |
|                   | 12ST_TAP  | 46  | 10   |                                                                     |              | 1.11        |                                                                                                                |
|                   | BACA      | 46  | 10   |                                                                     |              | 1.11        |                                                                                                                |
| 3                 | VALENCIA  | 115 | 10   |                                                                     | 1.1          | 1.10        |                                                                                                                |
|                   | VALENCIA  | 46  | 10   |                                                                     |              | 1.11        |                                                                                                                |
| 4                 | GALLINAT  | 115 | 10   |                                                                     | 1.1          | 1.10        |                                                                                                                |
| 5                 | BLACKLAK  | 69  | 10   |                                                                     |              | 1.10        |                                                                                                                |
| 6                 | BLACKLAK  | 115 | 10   |                                                                     | 1.1          | 1.09        |                                                                                                                |
| 7                 | ROWE_TAP  | 115 | 10   |                                                                     | 1.1          | 1.08        |                                                                                                                |
| 8                 | SPRINGER  | 69  | 10   |                                                                     |              | 1.17        |                                                                                                                |
| 9                 | SPRINGER  | 115 | 10   |                                                                     | 1.1          | 1.11        |                                                                                                                |
| 10                | STORRIE   | 115 | 10   |                                                                     | 1.1          | 1.10        |                                                                                                                |
| 11                | YORKCANY  | 69  | 10   |                                                                     |              | 1.15        |                                                                                                                |
| 12                | YORKCANY  | 115 | 10   |                                                                     | 1.1          | 1.12        |                                                                                                                |
| 13                | RAINSVIL  | 115 | 10   |                                                                     | 1.1          | 1.11        |                                                                                                                |
| 14                | RAINSVILX | 115 | 10   |                                                                     | 1.1          | 1.11        |                                                                                                                |
| 17                | BISON     | 115 | 10   |                                                                     | 1.1          | 1.11        |                                                                                                                |
| 18                | CIMARRON  | 115 | 10   |                                                                     | 1.1          | 1.11        |                                                                                                                |

Other notable observations: The Walsenburg-Gladstone contingency in the post project heavy winter case results in the solution diverging due to voltage rising when the Remedial Action Scheme (RAS) sheds load. Not allowing the RAS to shed load in the heavy winter case mitigates the voltage rising which causes a no solution. In the heavy summer case, the Walsenburg – Gladstone contingency solves but has post contingency voltages in the range of 1.11 to 1.24 pu. Again this can be mitigated by eliminating the load shedding on the Walsenburg –Gladstone RAS. If the project moves forward further modification to the RAS will be necessary.



## Short-Circuit Analysis Results

A short circuit study was conducted to determine if the existing circuit breakers are sufficient to accommodate the MLTP. Based on these results, the existing circuit breakers are adequate. See Appendix E for detailed information.

## Transient Stability Analysis Results

The study results showed that the new Mora line did not cause any transient stability violations, for all single and double contingencies studied. This analysis only captured transient stability performance with an estimate of how Gallegos collector generation might perform given the plan of the MLTP. A subsequent System Impact Study will be performed when a Transmission Service Request is made which will verify acceptable system performance for the final design of the Gallegos collector system and wind turbines.

For the HW case, the P1 contingency of Gladstone – Springer 115 kV diverged in the pre-MLTP and post-MLTP case. Evaluating the solution of the dynamic simulation revealed there was insufficient reactive support at Rosebud due to voltage collapse. This analysis was followed up by installing a Rosebud 115 kV shunt capacitor (30 Mvar), and it resolved the convergence issue. Note: The shunt capacitance requirements at Rosebud were not optimized during this study.

Other non-MLTP issues are noted below.

The Bravo Dome out-of-step relay protection (ooslen) opened the Clapham – Rosebud 115 kV line for the loss of the Gladstone – Springer 115 kV both pre and post-MLTP for each case, and subsequently on the loss of Gladstone – Springer TSGT & MLTP 115 kV for the HS and LSpr cases. It also operated for the loss of the Walsenburg – Gladstone 230 kV line in the HS case both pre and post-MLTP, and for the breaker failure scenario of the Jicarilla – San Juan and the Jicarilla - Ojo lines in the pre-MLTP case only. In all cases, its operation originates pre-MLTP.

An angle violation at TA-3-AL was seen both pre and post MLTP for the below contingencies in the HW case. HW is the only season with this unit on (or any unit at this bus). Netting the generator model at this bus resolved the problem. This issue was not triggered by the MLTP.

- P1: West Mesa – Arroyo PS 345 kV
- P1: Cabezón – Rio Puerco 345 kV
- P1: San Juan – Jicarilla 345 kV
- P1: BA-Norton 345 kV
- P4: BA-Rio Puerco #1 & #2 345 kV

Updates to the dynamic file and cases are noted below.

The following TSGT changes were made to the dynamic models (dyd) file.

- Update the old Clapham 50 MVAR SVC “vwsc” model with the “svwsc” model
- Add the Bravo Dome out-of-step relay protection (Clapham-Rosebud 115 kV)
- Add the UVLS to drop Hilltop/Springfield loads (tlin1)

The following changes were made to the customer dynamic data (Gallegos Collector generation):

- The reference buses in the repc\_a and lhvrt models referred to a 230 kV bus. This was updated to the 115 kV Gallegos Collector bus.
- The regc\_a and reec\_a models were modified to eliminate ringing at the generator buses and other nearby buses in the HW case for the following contingencies: Gladstone-Springer 115 kV, Walsenburg-Gladstone 230 kV, Valencia-Zia 115 kV, Taos-Springer 115kV, and Springer-Gladstone TSGT & MLTP 115 kV. See Appendix for details.

The power flow analysis modeled the Gallegos Collector generation at the Gallegos Collector 115 kV bus, but the dynamic data file (dyd) provided later had the generator at 0.69 kV. Thus for the transient stability analysis the generator modeling was updated to include two transformers: 115/34.5 kV and 34.5/0.69 kV. No collector system was modeled since no data was supplied for it. A fixed tap was added on the 34.5/0.69 kV transformer to keep the generator bus at a reasonable voltage.

## Transmission Interconnection Facilities

The cost and schedule for the interconnection of the MLTP to the PNM and the TSGT facilities are summarized below. These estimated costs and construction schedules were developed by PNM and TSGT for their respective interconnection to MLTP. The Facility Study will provide a detail cost estimate and schedule. Both PNM and TSGT will develop their own Facility Study that will be incorporated into their wires-to-wires interconnection agreement with MLTP.

| Transmission Interconnection Facilities                                                                                                                              | Cost        | Construction time | Utility |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|-------------------|---------|
| Construct a new 3 breaker ring at the intersection of the Valencia – Storrie 115 kV line and Arriba Tap 115 kV transmission line.                                    | 8.25        | 18 months         | PNM     |
| Interconnect Arriba Station to MLTP via 1 115 kV breaker                                                                                                             | 1.0         | 6 months          | PNM     |
| Install new line positions, associated dead ends, 4-115kV circuit breakers, 5-115kV disconnects, CCVTs and metering to terminate MLTP at Springer Switching Station  | 2.74        | 24 months         | TSGT    |
| Install new line positions, associated dead ends, 5-115kV circuit breakers, 8-115kV disconnects, CCVTs and metering to terminate MLTP at Gladstone Switching Station | 3.16        | 24 months         | TSGT    |
| <b>Total</b>                                                                                                                                                         | <b>15.2</b> | <b>24 months</b>  |         |




## Appendix A – Power Flow Plots

Diagrams for the following post-Project cases are provided:


1. 20 Heavy Summer
2. 21 Heavy Winter
3. 17 Light Spring

Confidential: Sean Black (ID 68709) | sblack2@ameren.com | Ameren on 2019-03-05

## Mora Transmission Line SIS, 2020 HS Post-Project



# Mora Transmission Line SIS, 2021 HW Post-Project



General Electric International, Inc. PSLF Program Wed Sep 14 17:01:35 2016 04b 21hw1a post 160MW Blklk-1035 r1 pf.sav




2021 HW Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.

WECC 2020-2021 HW1 PLANNING CASE 9/14/15

MW/MVAR  
gediworkScan.drw  
Rating = 1

# Mora Transmission Line SIS, 2017 Light Spring Post-Project



General Electric International, Inc. PSLF Program Wed Sep 14 16:14:45 2016 06\_17lsp\_post\_160MW\_pf.sav



2017 LSP Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.

WECC 2017 LSP1-S PLANNING CASE 11/6/14

MW/MVAR  
PNM\_MoraSIS\_post\_r3b.drw  
Rating = 1




## Appendix B – Transient Stability Plots

This appendix provides a sample of the transient stability plots run as part of this study. Additional plots may be provided on request.


The plots represent the post-project case with generation dispatched at 160 MW. Plots for the following contingencies are provided:

| NO.                  | CONTINGENCY DESCRIPTION                     |                                                                               | CLEARING TIME (CYCLES) | SEASON |
|----------------------|---------------------------------------------|-------------------------------------------------------------------------------|------------------------|--------|
| All Lines in Service |                                             |                                                                               |                        |        |
| 1                    | FLAT RUN                                    |                                                                               |                        | 17 LSp |
| P1 Contingencies     |                                             |                                                                               |                        |        |
| 2                    | Cabezon –Rio Puerco 345 kV                  | 3-phase fault near RIO PUERCO 345 kV                                          | 4                      | 17 LSp |
| 3                    | Gladstone - Springer 115 kV #1              | 3-phase fault near GLADSTONE 115 kV                                           | 4                      | 17 LSp |
| 4                    | Walsenburg – Gladstone 230 kV               | 3-phase fault near GLADSTONE 230 kV                                           | 4                      | 17 LSp |
| 5                    | Valencia – Zia 115 kV                       | 3-phase fault near VALENCIA 115 kV                                            | 4                      | 21 HW  |
| 6                    | Taos - Springer 115 kV                      | 3-phase fault near TAOS 115 kV                                                | 4                      | 21 HW  |
| P4 Contingencies     |                                             |                                                                               |                        |        |
| 7                    | San Juan-Jicarilla & Jicarilla-Ojo          | 3-phase fault near JICARILLA 115 kV<br>Delayed clearing of Jicarilla-Ojo line | 4, 12                  | 21 HW  |
| P7 Contingencies     |                                             |                                                                               |                        |        |
| 8                    | Springer – Gladstone #1 & #3 (post-Project) | 3-phase fault near GLADSTONE 115 kV                                           | 4                      | 21 HW  |


# MORA Transient Stability Plots




|   |        |   |      |       |                |   |     |        |   |   |        |
|---|--------|---|------|-------|----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12082 | TACS 345.0     | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10116 | GUADLUPE 345.0 | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10390 | RIOPURSC 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 10025 | B-A 115.0      | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 10369 | WESTMESA 345.0 | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |




|   |         |   |      |       |                |   |     |        |   |   |         |
|---|---------|---|------|-------|----------------|---|-----|--------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12082 | TACS 345.0     | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 10116 | GUADLUPE 345.0 | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 10390 | RIOPURSC 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 10025 | B-A 115.0      | 0 | 0.0 | fmeta  | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 10369 | WESTMESA 345.0 | 0 | 0.0 | fmeta  | 1 | 1 | 60.5000 |




|   |        |   |      |       |                |   |     |       |   |   |        |
|---|--------|---|------|-------|----------------|---|-----|-------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 12079 | STORIE 115.0   | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |



|   |         |   |      |       |                |   |     |       |   |   |         |
|---|---------|---|------|-------|----------------|---|-----|-------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 12079 | STORIE 115.0   | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |



|   |        |   |      |       |                 |   |     |        |   |   |        |
|---|--------|---|------|-------|-----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | regc_a | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |









|   |         |   |      |       |                 |   |     |        |   |   |         |
|---|---------|---|------|-------|-----------------|---|-----|--------|---|---|---------|
| o | 59.2000 | 2 | fbus | 10016 | AREIBA 115.0    | 0 | 0.0 | regc_a | 1 | 1 | 60.7000 |
| x | 59.2000 | 2 | fbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |
| □ | 59.2000 | 2 | fbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |
| Δ | 59.2000 | 2 | fbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |

2017 LSP Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
1 01\_N-0\_FLAT\_RUN




MORA  
Transient Stability Plots




2017 LSP Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
1 01\_N-0\_FLAT\_RUN




MORA  
Transient Stability Plots




|   |        |   |      |       |                 |   |     |        |   |   |        |
|---|--------|---|------|-------|-----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12082 | TACS 345.0      | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10116 | GUADLUPE 345.0  | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10390 | RIOPUERCO 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 10025 | B-A 115.0       | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 10369 | WESTMESA 345.0  | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |




|   |         |   |      |       |                 |   |     |        |   |   |         |
|---|---------|---|------|-------|-----------------|---|-----|--------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12082 | TACS 345.0      | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 10116 | GUADLUPE 345.0  | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 10390 | RIOPUERCO 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 10025 | B-A 115.0       | 0 | 0.0 | fmeta  | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 10369 | WESTMESA 345.0  | 0 | 0.0 | fmeta  | 1 | 1 | 60.5000 |




|   |        |   |      |       |                |   |     |       |   |   |        |
|---|--------|---|------|-------|----------------|---|-----|-------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 12079 | STORIE 115.0   | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |



|   |         |   |      |       |                |   |     |       |   |   |         |
|---|---------|---|------|-------|----------------|---|-----|-------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 12079 | STORIE 115.0   | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |



|   |        |   |      |       |                 |   |     |        |   |   |        |
|---|--------|---|------|-------|-----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | regc_a | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |









|   |         |   |      |       |                 |   |     |        |   |   |         |
|---|---------|---|------|-------|-----------------|---|-----|--------|---|---|---------|
| o | 59.2000 | 2 | fbus | 10016 | AREIBA 115.0    | 0 | 0.0 | regc_a | 1 | 1 | 60.7000 |
| x | 59.2000 | 2 | fbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |
| □ | 59.2000 | 2 | fbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |
| Δ | 59.2000 | 2 | fbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |

2017 LSP Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
3 03\_Cab-RioPuerco\_345\_4c









# MORA Transient Stability Plots



2017 LSP Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
3 03\_Cab-RioPuerc\_345\_4c









MORA  
Transient Stability Plots



2017 LSP Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
5 05\_GLAD-SPR\_4c


# MORA Transient Stability Plots




2017 LSP Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
5 05\_GLAD-SPR\_4c




MORA  
Transient Stability Plots




|   |        |   |      |       |                |   |     |        |   |   |        |
|---|--------|---|------|-------|----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12082 | TACS 345.0     | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10116 | GUADLUPE 345.0 | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10390 | RIOPURSC 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 10025 | B-A 115.0      | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 10369 | WESTMESA 345.0 | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |




|   |         |   |      |       |                |   |     |        |   |   |         |
|---|---------|---|------|-------|----------------|---|-----|--------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12082 | TACS 345.0     | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 10116 | GUADLUPE 345.0 | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 10390 | RIOPURSC 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 10025 | B-A 115.0      | 0 | 0.0 | fmeta  | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 10369 | WESTMESA 345.0 | 0 | 0.0 | fmeta  | 1 | 1 | 60.5000 |




|   |        |   |      |       |                |   |     |       |   |   |        |
|---|--------|---|------|-------|----------------|---|-----|-------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 12079 | STORIE 115.0   | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |



|   |         |   |      |       |                |   |     |       |   |   |         |
|---|---------|---|------|-------|----------------|---|-----|-------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 12079 | STORIE 115.0   | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |



|   |        |   |      |       |                 |   |     |        |   |   |        |
|---|--------|---|------|-------|-----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | regc_a | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |









|   |         |   |      |       |                 |   |     |        |   |   |         |
|---|---------|---|------|-------|-----------------|---|-----|--------|---|---|---------|
| o | 59.2000 | 2 | fbus | 10016 | AREIBA 115.0    | 0 | 0.0 | regc_a | 1 | 1 | 60.7000 |
| x | 59.2000 | 2 | fbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |
| □ | 59.2000 | 2 | fbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |
| Δ | 59.2000 | 2 | fbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |

2017 LSP Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
7 07\_WALS-GLAD\_4c




# MORA Transient Stability Plots




2017 LSP Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
7 07\_WALS-GLAD\_4c




# MORA Transient Stability Plots




|   |        |   |      |       |                |   |     |        |   |   |        |
|---|--------|---|------|-------|----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12082 | TACS 345.0     | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10116 | GUADLUPE 345.0 | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10390 | RIOPUECO 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 10025 | B-A 115.0      | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 10369 | WESTMESA 345.0 | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |




|   |         |   |      |       |                |   |     |        |   |   |         |
|---|---------|---|------|-------|----------------|---|-----|--------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12082 | TACS 345.0     | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 10116 | GUADLUPE 345.0 | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 10390 | RIOPUECO 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 10025 | B-A 115.0      | 0 | 0.0 | fmeta  | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 10369 | WESTMESA 345.0 | 0 | 0.0 | fmeta  | 1 | 1 | 60.5000 |




|   |        |   |      |       |                |   |     |       |   |   |        |
|---|--------|---|------|-------|----------------|---|-----|-------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 12079 | STORIE 115.0   | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |



|   |         |   |      |       |                |   |     |       |   |   |         |
|---|---------|---|------|-------|----------------|---|-----|-------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 12079 | STORIE 115.0   | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |



|   |        |   |      |       |                 |   |     |        |   |   |        |
|---|--------|---|------|-------|-----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | regc_a | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |









|   |         |   |      |       |                 |   |     |        |   |   |         |
|---|---------|---|------|-------|-----------------|---|-----|--------|---|---|---------|
| o | 59.2000 | 2 | fbus | 10016 | AREBA 115.0     | 0 | 0.0 | regc_a | 1 | 1 | 60.7000 |
| x | 59.2000 | 2 | fbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |
| □ | 59.2000 | 2 | fbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |
| Δ | 59.2000 | 2 | fbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |

2021 HW Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
8 08b\_VAL-ZIA\_4c




# MORA Transient Stability Plots




2021 HW Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
8 08b\_VAL-ZIA\_4c




# MORA Transient Stability Plots




|   |        |   |      |       |                 |   |     |        |   |   |        |
|---|--------|---|------|-------|-----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12082 | TACS 345.0      | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10116 | GUADLUPE 345.0  | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10390 | RIOFUERTE 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 10025 | B-A 115.0       | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 10369 | WESTMESA 345.0  | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |




|   |         |   |      |       |                 |   |     |        |   |   |         |
|---|---------|---|------|-------|-----------------|---|-----|--------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12082 | TACS 345.0      | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 10116 | GUADLUPE 345.0  | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 10390 | RIOFUERTE 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 10025 | B-A 115.0       | 0 | 0.0 | fmata  | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 10369 | WESTMESA 345.0  | 0 | 0.0 | fmata  | 1 | 1 | 60.5000 |




|   |        |   |      |       |                |   |     |       |   |   |        |
|---|--------|---|------|-------|----------------|---|-----|-------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 12079 | STORIE 115.0   | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |



|   |         |   |      |       |                |   |     |       |   |   |         |
|---|---------|---|------|-------|----------------|---|-----|-------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | fmata | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | fmata | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 12079 | STORIE 115.0   | 0 | 0.0 | fmata | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | fmata | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | fmata | 1 | 1 | 60.5000 |



|   |        |   |      |       |                 |   |     |        |   |   |        |
|---|--------|---|------|-------|-----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | regc_a | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |









|   |         |   |      |       |                 |   |     |        |   |   |         |
|---|---------|---|------|-------|-----------------|---|-----|--------|---|---|---------|
| o | 59.2000 | 2 | fbus | 10016 | ADELIA 115.0    | 0 | 0.0 | regc_a | 1 | 1 | 60.7000 |
| x | 59.2000 | 2 | fbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | fmata  | 1 | 1 | 60.7000 |
| □ | 59.2000 | 2 | fbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | fmata  | 1 | 1 | 60.7000 |
| Δ | 59.2000 | 2 | fbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | fmata  | 1 | 1 | 60.7000 |

2021 HW Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
9 09a\_TAOS-SPR\_4c




# MORA Transient Stability Plots




2021 HW Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
9 09a\_TAOS-SPR\_4c




# MORA Transient Stability Plots




|   |        |   |      |       |                |   |     |        |   |   |        |
|---|--------|---|------|-------|----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12082 | TACS 345.0     | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10116 | GUADLUPE 345.0 | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10390 | RIOPURSC 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 10025 | B-A 115.0      | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 10369 | WESTMESA 345.0 | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |




|   |         |   |      |       |                |   |     |        |   |   |         |
|---|---------|---|------|-------|----------------|---|-----|--------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12082 | TACS 345.0     | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 10116 | GUADLUPE 345.0 | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 10390 | RIOPURSC 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 10025 | B-A 115.0      | 0 | 0.0 | fmeta  | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 10369 | WESTMESA 345.0 | 0 | 0.0 | fmeta  | 1 | 1 | 60.5000 |




|   |        |   |      |       |                |   |     |       |   |   |        |
|---|--------|---|------|-------|----------------|---|-----|-------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 12079 | STORIE 115.0   | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |



|   |         |   |      |       |                |   |     |       |   |   |         |
|---|---------|---|------|-------|----------------|---|-----|-------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 12079 | STORIE 115.0   | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | fmeta | 1 | 1 | 60.5000 |



|   |        |   |      |       |                 |   |     |        |   |   |        |
|---|--------|---|------|-------|-----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | regc_a | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |









|   |         |   |      |       |                 |   |     |        |   |   |         |
|---|---------|---|------|-------|-----------------|---|-----|--------|---|---|---------|
| o | 59.2000 | 2 | fbus | 10016 | AREIRA 115.0    | 0 | 0.0 | regc_a | 1 | 1 | 60.7000 |
| x | 59.2000 | 2 | fbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |
| □ | 59.2000 | 2 | fbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |
| Δ | 59.2000 | 2 | fbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | fmeta  | 1 | 1 | 60.7000 |

2021 HW Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
11 12\_P4\_JIC-SJ and JIC-OJO




# MORA Transient Stability Plots




2021 HW Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
11 12\_P4\_JIC-SJ and JIC-OJO




# MORA Transient Stability Plots




|   |        |   |      |       |                 |   |     |        |   |   |        |
|---|--------|---|------|-------|-----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12082 | TACS 345.0      | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10116 | GUADLUPE 345.0  | 0 | 0.0 | genrou | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10390 | RIOPUERCO 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 10025 | B-A 115.0       | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 10369 | WESTMESA 345.0  | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |




|   |         |   |      |       |                 |   |     |        |   |   |         |
|---|---------|---|------|-------|-----------------|---|-----|--------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12082 | TACS 345.0      | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 10116 | GUADLUPE 345.0  | 0 | 0.0 | genrou | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 10390 | RIOPUERCO 345.0 | 0 | 0.0 | gentpf | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 10025 | B-A 115.0       | 0 | 0.0 | fmata  | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 10369 | WESTMESA 345.0  | 0 | 0.0 | fmata  | 1 | 1 | 60.5000 |




|   |        |   |      |       |                |   |     |       |   |   |        |
|---|--------|---|------|-------|----------------|---|-----|-------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 12079 | STORIE 115.0   | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| Δ | 0.0000 | 2 | vbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |
| ◇ | 0.0000 | 2 | vbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | vmeta | 1 | 1 | 1.2000 |



|   |         |   |      |       |                |   |     |       |   |   |         |
|---|---------|---|------|-------|----------------|---|-----|-------|---|---|---------|
| o | 59.5000 | 2 | fbus | 12100 | GLADSTON 115.0 | 0 | 0.0 | fmata | 1 | 1 | 60.5000 |
| x | 59.5000 | 2 | fbus | 12077 | SPRINGER 115.0 | 0 | 0.0 | fmata | 1 | 1 | 60.5000 |
| □ | 59.5000 | 2 | fbus | 12079 | STORIE 115.0   | 0 | 0.0 | fmata | 1 | 1 | 60.5000 |
| Δ | 59.5000 | 2 | fbus | 12062 | ROSEBUD 115.0  | 0 | 0.0 | fmata | 1 | 1 | 60.5000 |
| ◇ | 59.5000 | 2 | fbus | 12011 | BLACKLAK 115.0 | 0 | 0.0 | fmata | 1 | 1 | 60.5000 |



|   |        |   |      |       |                 |   |     |        |   |   |        |
|---|--------|---|------|-------|-----------------|---|-----|--------|---|---|--------|
| o | 0.0000 | 2 | vbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | regc_a | 1 | 1 | 1.2000 |
| x | 0.0000 | 2 | vbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |
| □ | 0.0000 | 2 | vbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | vmeta  | 1 | 1 | 1.2000 |









|   |         |   |      |       |                 |   |     |        |   |   |         |
|---|---------|---|------|-------|-----------------|---|-----|--------|---|---|---------|
| o | 59.2000 | 2 | fbus | 10016 | AREIBA 115.0    | 0 | 0.0 | regc_a | 1 | 1 | 60.7000 |
| x | 59.2000 | 2 | fbus | 12038 | HERNANDEZ 115.0 | 0 | 0.0 | fmata  | 1 | 1 | 60.7000 |
| □ | 59.2000 | 2 | fbus | 10357 | VALENCIA 115.0  | 0 | 0.0 | fmata  | 1 | 1 | 60.7000 |
| Δ | 59.2000 | 2 | fbus | 10386 | ZIA_1 115.0     | 0 | 0.0 | fmata  | 1 | 1 | 60.7000 |

2021 HW Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
12 11\_P7\_SPR-GLAD\_1\_3



# MORA Transient Stability Plots



2021 HW Case, Mora TL SIS  
Post-project. 160 MW. Offset gen at Navajo.  
12 11\_P7\_SPR-GLAD\_1\_3





## Appendix C – Dynamic Data

In order to study the Mora Transmission Line Project, generation models were needed for the associated generation. This appendix documents the dynamic models used. The regc\_a and reec\_a models were updated from the original data provided to eliminate ringing as noted in the main report.

- regc\_a
- reec\_a
- wtgq\_a
- wtgt\_a
- wtga\_a
- wtgp\_a
- repc\_a
- lhvrt

**regc\_a:** Generator/converter model

| Variable        | Original Data | Project Data  | PSLF Default |
|-----------------|---------------|---------------|--------------|
| <b>MVA Base</b> |               | <b>199.33</b> |              |
| Lvplsw          | 1             | 1             | 1            |
| Rrpwr           | 10            | 10            | 10           |
| Brkpt           | 0.9           | 0.9           | 0.9          |
| Zerox           | 0.5           | 0.5           | 0.5          |
| Lvpl1           | 1.22          | 1.22          | 1.22         |
| Vtmax           | 1.2           | 1.2           | 1.2          |
| Lvpnt1          | 0.8           | 0.8           | 0.8          |
| Lvpnt0          | 0.4           | 0.4           | 0.4          |
| Qmin            | -1.3          | -1.3          | -1.3         |
| Accel           | 0.7           | 0.7           | 0.7          |
| Tg              | 0.02          | 0.02          | 0.02         |
| Tfltr           | 0.02          | 0.02          | 0.02         |
| lqrmax          | 999           | 99            | 99           |
| lqrmin          | -999          | -99           | -99          |
| Xe              | 0             | 0.8           | 0            |

**reec\_a:** Renewable energy electrical control model

| Variable | Original Data | Project Data | PSLF Default |
|----------|---------------|--------------|--------------|
| mvab     | 0             | 0            |              |
| Vdip     | 0             | -99          | -99          |
| Vup      | 2             | 99           | 99           |
| Trv      | 0.02          | 0            | 0            |
| dbd1     | 0             | -0.05        | -0.05        |
| dbd2     | 0             | 0.05         | 0.05         |
| kqv      | 0             | 0            | 0            |
| iqh1     | 1             | 1.05         | 1.05         |
| iq11     | -1            | -1.05        | -1.05        |



|        |        |        |        |
|--------|--------|--------|--------|
| vref0  | 1.03   | 1.03   | 0      |
| iqfrz  | 0      | 0.15   | 0.15   |
| thld   | 0      | 0      | 0      |
| thld2  | 0      | 0      | 0      |
| Tp     | 0.02   | 0.05   | 0.05   |
| qmax   | 0.436  | 0.436  | 0.436  |
| qmin   | -0.436 | -0.436 | -0.436 |
| vmax   | 1.1    | 1.1    | 1.1    |
| vmin   | 0.9    | 0.9    | 0.9    |
| Kqp    | 0      | 0      | 0      |
| Kqi    | 0.41   | 0.1    | 0.5    |
| Kvp    | 0      | 0      | 0      |
| Kvi    | 40     | 40     | 40     |
| vref1  | 0      | 0      | 0      |
| Tiq    | 0.02   | 0.02   | 0.02   |
| dpmax  | 0.45   | 99     | 99     |
| dpmin  | -0.45  | -99    | -99    |
| pmax   | 1.12   | 1      | 1.12   |
| pmin   | 0.04   | 0      | 0.04   |
| Imax   | 1.7    | 1.82   | 1.82   |
| tpord  | 0.02   | 0.02   | 0.02   |
| pfflag | 0      | 0      | 0      |
| vflag  | 1      | 1      | 1      |
| qflag  | 1      | 1      | 1      |
| pflag  | 0      | 0      | 0      |
| pqflag | 0      | 0      | 0      |
| vq1    | 0      | -1     | -1     |
| iq1    | 0      | 1.45   | 1.45   |
| vq2    | 0.4    | 2      | 2      |
| iq2    | 1.1    | 1.45   | 1.45   |
| vq3    | 0.8    | 0      | 0      |
| iq3    | 1.1    | 0      | 0      |
| vq4    | 2      | 0      | 0      |
| iq4    | 1.1    | 0      | 0      |
| vp1    | 0      | -1     | -1     |
| ip1    | 0      | 1.1    | 1.1    |
| vp2    | 0.4    | 2      | 2      |
| ip2    | 1.1    | 1.1    | 1.1    |
| vp3    | 0.8    | 0      | 0      |
| ip3    | 1.1    | 0      | 0      |
| vp4    | 2      | 0      | 0      |
| ip4    | 1.1    | 0      | 0      |

**wtgq\_a:** WTG Torque controller

| Variable | Original/Project Data |
|----------|-----------------------|
| mvab     | 0                     |
| kip      | 0.6                   |
| kpp      | 3                     |
| tp       | 0.05                  |
| twref    | 60                    |



|       |      |
|-------|------|
| temax | 1.2  |
| temin | 0.08 |
| p1    | 0.2  |
| spd1  | 0.69 |
| p2    | 0.4  |
| spd2  | 0.78 |
| p3    | 0.6  |
| spd3  | 0.98 |
| p4    | 0.74 |
| spd4  | 1.2  |
| tflag | 1    |

**wtgt\_a:** Drive train model

| Variable | Original/Project Data |
|----------|-----------------------|
| mvab     | 0                     |
| ht       | 3.22                  |
| hg       | 0.62                  |
| dshaft   | 1.5                   |
| kshaft   | 0                     |
| wo       | 1.2                   |

**wtga\_a:** Simple aerodynamic model

| Variable | Original/Project Data |
|----------|-----------------------|
| mvab     | 0                     |
| ka       | 0.01                  |
| theta0   | 0                     |

**wtgp\_a:** WTG Pitch controller

| Variable | Original/Project Data |
|----------|-----------------------|
| Mvab     | 0                     |
| kiw      | 25                    |
| kpw      | 150                   |
| kic      | 30                    |
| kpc      | 3                     |
| kcc      | 0                     |
| tpi      | 0.3                   |
| pimax    | 27                    |
| pimin    | 0                     |
| piratmx  | 10                    |
| piratmn  | -10                   |

**repc\_a:** Power Plant Controller

| Variable | Original/Project Data |
|----------|-----------------------|
| Mvab     | 0                     |
| tfltr    | 0.02                  |



|         |       |
|---------|-------|
| kp      | 2     |
| ki      | 1     |
| tft     | 0     |
| tfv     | 0.15  |
| refflg  | 1     |
| vfrz    | 0.7   |
| rc      | 0     |
| xc      | 0     |
| kc      | 0     |
| vcmpflg | 0     |
| emax    | 0.1   |
| emin    | -0.1  |
| dbd     | 0     |
| qmax    | 0.44  |
| qmin    | -0.44 |
| kpg     | 0     |
| kig     | 0     |
| tp      | 0.02  |
| fdbd1   | 0     |
| fdbd2   | 0     |
| Femax   | 1     |
| Femin   | 0     |
| Pmax    | 1     |
| Pmin    | 0.08  |
| Tlag    | 1     |
| ddn     | 0.99  |
| dup     | 0.99  |
| frqflg  | 0     |
| outflag | 0     |
| Puflag  | 0     |

**lhvrt:** Low/High Voltage Ride Through generator protection

| Variable | Original/Project Data |
|----------|-----------------------|
| vref     | 1                     |
| dvtrp1   | -0.6                  |
| dvtrp2   | -0.4                  |
| dvtrp3   | -0.25                 |
| dvtrp4   | -0.15                 |
| dvtrp5   | -0.1                  |
| dvtrp6   | 0.101                 |
| dvtrp7   | 0.15                  |
| dvtrp8   | 0.175                 |
| dvtrp9   | 0.2                   |
| dvtrp10  | 0.3                   |
| dttrp1   | 1                     |
| dttrp2   | 1.7                   |
| dttrp3   | 2.2                   |
| dttrp4   | 10                    |
| dttrp5   | 600                   |



|         |      |
|---------|------|
| dttrp6  | 1    |
| dttrp7  | 0.5  |
| dttrp8  | 0.2  |
| dttrp9  | 0.1  |
| dttrp10 | 0.01 |
| alarm   | 0    |

Confidential: Sean Black (ID 68709) | sblack2@ameren.com | Ameren on 2019-03-05



## Appendix D – Short Circuit Analysis

Confidential: Sean Black (ID 68709) | sblack2@ameren.com | Ameren on 2019-03-05



---

## Pre- Project Short Circuit – Analysis

Confidential: Sean Black (ID 68709) | sblack2@ameren.com | Ameren on 2019-03-05

Without Lucky Corridor Project

-- ASPEN OneLiner(Tm) --  
VERSION 14.4

DATE AND TIME: Sun Dec 18 20:58:19 2016

OLR FILE NAME: D:\BREAKER-TPL-FAC002\2016TPL-BASE LATE-VERDE -LUCKY.OLR

STUDY DATE: None

NAME OF THIS FILE: D:\BREAKER-TPL-FAC002\REPORTS\LuckyCorridor OUT.TXT

BASE MVA = 100.  
THIS FILE HAS: 444 BUSES  
67 GENERATORS  
0 LOADS  
43 SHUNTS  
326 LINES  
101 2-WINDING TRANSFORMERS  
54 3-WINDING TRANSFORMERS  
2 PHASE SHIFTERS  
16 SWITCHES  
4 SERIES CAPCITORS. 0 BYPASSED  
3 SERIES REACTORS. 3 BYPASSED  
8 MUTUAL COUPLING PAIRS

FILE COMMENTS:..... 2013 Q4 modified as below  
w.....

Added Britton sw sta on AW line, Snow Vista on PW line and Scenic on CE line  
Added annotated comment for OOS facilities  
Added Lajara 115kv line to Algodones and associate 69kv TRIS loop  
Added El Cerro, Manzano and Palace Taps on AT line

\_\_\_\_\_ 2014 Q1 MODIFICATIONS \_\_\_\_\_

Added Jicarilla station on OJ 345kV line  
Added Ojo 300MVA auto ISD 2014 (OOS)  
Added Freeport Mining Facilites-MD1 area  
Revised HLM transformer Z

xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx 2014 Q2 MODIFICATIONS xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx  
xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx  
Added Richmond Station, tied to Prager, North and Sandia, via PN, EB-CG-HW line  
sections. Left OOS  
Removed Bus Tie Reactor at WM1-2, replaced with switch N.C.

-----2015 FUT MODIFICATIONS -----  
-----

Bussed 345kV line into Rio Puerco  
Adder PR line Progress-Rio Puerco 115kV

PREFault VOLTAGE PROFILE: FLAT BUS VOLTAGES. PREFault V=1 PU  
GENERATOR IMPEDANCE: SUBTRANSIENT  
IGNORE PHASE SHIFT [ ]  
IGNORE LOADS [ ]

|                                             |     |
|---------------------------------------------|-----|
| IGNORE TRANSMISSION LINE G+jB               | [ ] |
| IGNORE SHUNTS WITH + SEQ IMPEDANCE          | [ ] |
| IGNORE TRANSFORMER LINE SHUNTS              | [ ] |
| MOV ITERATION                               | [X] |
| GENERATOR CURRENT LIMIT                     | [ ] |
| SIMULATE VOLTAGE CONTROLLED CURRENT SOURCES | [ ] |

=====

Confidential: Sean Black (ID 68709) | sblack2@ameren.com | Ameren on 2019-03-05

PAGE 2 Bus Fault on: 0 ZIA 1 115. kV 3LG

```

=====
1. Bus Fault on:      0 ZIA 1      115. kV 3LG

                        FAULT CURRENT (PU @ DEG)
                        + SEQ      - SEQ      0 SEQ      A PHASE      B PHASE      C PHASE
19.065@ -80.4      0.000@  0.0      0.000@  0.0      19.065@ -80.4      19.065@ 159.6      19.065@ 39.6
                        THEVENIN IMPEDANCE (PU)
0.00872+j0.05172    0.00872+j 0.0516    0.00811+j0.05434

SHORT CIRCUIT MVA= 1906.5      X/R RATIO= 5.92949      R0/X1= 0.15686      X0/X1= 1.0507
-----
BUS      0 ZIA 1      115.KV      AREA 1      ZONE 1      TIER 0      (PREFault V=1.000@ 0.0 PU)
                        + SEQ      - SEQ      0 SEQ      A PHASE      B PHASE      C PHASE
VOLTAGE (KV, L-G)      >      0.000@  0.0      0.000@  0.0      0.000@  0.0      0.000@  0.0      0.000@  0.0
BRANCH CURRENT (PU) TO      >
0 ANZ TP      115. 1L      7.825@ 100.2      0.000@  0.0      0.000@  0.0      7.825@ 100.2      7.825@ -19.8      7.825@-139.8
66 VALENCIA      115. 1L      0.838@ 105.0      0.000@  0.0      0.000@  0.0      0.838@ 105.0      0.838@ -15.0      0.838@-135.0
7 B-A      115. 1L      3.519@ 102.8      0.000@  0.0      0.000@  0.0      3.519@ 102.8      3.519@ -17.2      3.519@-137.2
0 ZIA 2      46. X      0.000@  0.0      0.000@  0.0      0.000@  0.0      0.000@  0.0      0.000@  0.0
0 Z3TERT      13.8 X
      AUTO NEUTRAL CURRENT =      0.0 @ -177.5 A
73 ZIA 2      115. S      6.902@ 96.6      0.000@  0.0      0.000@  0.0      6.902@ 96.6      6.902@ -23.4      6.902@-143.4
190 ZIA XFMR 1      7.2 1T      0.000@  0.0      0.000@  0.0      0.000@  0.0      0.000@  0.0      0.000@  0.0
191 ZIA XFMR 2      7.2 1T      0.000@  0.0      0.000@  0.0      0.000@  0.0      0.000@  0.0      0.000@  0.0

CURRENT TO FAULT (PU)      >      19.065@ -80.4      0.000@  0.0      0.000@  0.0      19.065@ -80.4      19.065@ 159.6      19.065@ 39.6
THEVENIN IMPEDANCE (PU)      >      0.05245@ 80.4      0.05233@ 80.4      0.05495@ 81.5
-----
EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU):
CAP FW 345.000kV -      RIO_PUERCO 345.000kV      0.000 + j-0.027      0.000 + j-0.027      0.000 + j-0.027
CAP WW 345.000kV -      RIO_PUERCO 345.000kV      0.000 + j-0.027      0.000 + j-0.027      0.000 + j-0.027
OJO 345.000kV -      OJO CAP 345.000kV      0.000 + j-0.037      0.000 + j-0.037      0.000 + j-0.037
=====

```

PAGE 3

Bus Fault on:

0 ZIA 1

115. kV 1LG Type=A

```

=====
2. Bus Fault on:          0 ZIA 1          115. kV 1LG Type=A
                        FAULT CURRENT (PU @ DEG)
                        + SEQ          - SEQ          0 SEQ          A PHASE          B PHASE          C PHASE
                        6.261@ -80.8      6.261@ -80.8      6.261@ -80.8      18.783@ -80.8      0.000@ 0.0      0.000@ 0.0
                        THEVENIN IMPEDANCE (PU)
                        0.00872+j0.05172  0.00872+j 0.0516  0.00811+j0.05434

                        SHORT CIRCUIT MVA= 1878.3      X/R RATIO= 6.16942      R0/X1= 0.15686      X0/X1= 1.0507
=====
BUS          0 ZIA 1          115.KV  AREA  1  ZONE  1  TIER  0      (PREFault V=1.000@ 0.0 PU)
                        + SEQ          - SEQ          0 SEQ          A PHASE          B PHASE          C PHASE
VOLTAGE (KV, L-G)      >          44.592@ 0.2      21.753@ 179.6      22.841@ 179.3      0.000@ 0.0      67.265@ -120.6      66.523@ 121.0
BRANCH CURRENT (PU) TO >
0 ANZ TP              115.  1L      2.570@ 99.8      2.570@ 99.8      1.747@ 102.2      6.885@ 100.4      0.828@ -85.3      0.828@ -85.3
66 VALENCIA           115.  1L      0.275@ 104.6      0.275@ 104.6      0.227@ 105.6      0.777@ 104.9      0.048@ -79.5      0.048@ -80.4
7 B-A                 115.  1L      1.156@ 102.4      1.156@ 102.4      0.478@ 108.0      2.787@ 103.4      0.682@ -81.6      0.682@ -81.5
0 ZIA 2               46.   X      0.000@ 0.0      0.000@ 0.0      0.984@ 90.7      0.984@ 90.7      0.984@ 90.7      0.984@ 90.7
0 Z3TERT              13.8  X
                        AUTO NEUTRAL CURRENT = 1482.1 @ 90.7 A
73 ZIA 2              115.  S      2.267@ 96.2      2.267@ 96.2      1.790@ 102.5      6.316@ 98.0      0.526@ -105.8      0.526@ -105.7
190 ZIA XFMR 1        7.2  1T      0.000@ 0.0      0.000@ 0.0      0.570@ 91.1      0.569@ 91.1      0.570@ 91.1      0.570@ 91.1
191 ZIA XFMR 2        7.2  1T      0.000@ 0.0      0.000@ 0.0      0.500@ 91.2      0.499@ 91.2      0.500@ 91.2      0.500@ 91.2

CURRENT TO FAULT (PU)  >          6.261@ -80.8      6.261@ -80.8      6.261@ -80.8      18.783@ -80.8      0.000@ 0.0      0.000@ 0.0
THEVENIN IMPEDANCE (PU) >          0.05245@ 80.4      0.05233@ 80.4      0.05495@ 81.5

=====
EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU):
CAP FW 345.000kV -    RIO_PUERCO 345.000kV      0.000 + j-0.027  0.000 + j-0.027  0.000 + j-0.027
CAP WW 345.000kV -    RIO_PUERCO 345.000kV      0.000 + j-0.027  0.000 + j-0.027  0.000 + j-0.027
OJO 345.000kV -       OJO CAP 345.000kV      0.000 + j-0.037  0.000 + j-0.037  0.000 + j-0.037
=====

```

PAGE 4 Bus Fault on: 66 VALENCIA 115. kV 3LG

|                                                                          |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
|--------------------------------------------------------------------------|-------------|-----------------|--------|----------------------|------------|---------------|------------|-----------------|--------------|-----------------|----------------------------|-----------------|--|-------------|--|
| =====                                                                    |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
| 3. Bus Fault on:                                                         |             | 66 VALENCIA     |        |                      |            | 115. kV 3LG   |            |                 |              |                 |                            |                 |  |             |  |
| FAULT CURRENT (PU @ DEG)                                                 |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
| + SEQ                                                                    |             | - SEQ           |        | 0 SEQ                |            | A PHASE       |            |                 |              | B PHASE         |                            |                 |  | C PHASE     |  |
| 3.783@ -73.9                                                             |             | 0.000@ 0.0      |        | 0.000@ 0.0           |            | 3.783@ -73.9  |            |                 |              | 3.783@ 166.1    |                            |                 |  | 3.783@ 46.1 |  |
| THEVENIN IMPEDANCE (PU)                                                  |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
| 0.07308+j0.25401                                                         |             | 0.0731+j0.25392 |        | 0.03684+j0.29683     |            |               |            |                 |              |                 |                            |                 |  |             |  |
| SHORT CIRCUIT MVA= 378.3                                                 |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
| X/R RATIO= 3.47574                                                       |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
| R0/X1= 0.14504                                                           |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
| X0/X1= 1.16859                                                           |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
| -----                                                                    |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
| BUS                                                                      | 66 VALENCIA |                 | 115.KV |                      | AREA       | 1             | ZONE       | 1               | TIER         | 0               | (PREFault V=1.000@ 0.0 PU) |                 |  |             |  |
|                                                                          |             | + SEQ           |        | - SEQ                |            | 0 SEQ         |            | A PHASE         |              | B PHASE         |                            | C PHASE         |  |             |  |
| VOLTAGE (KV, L-G)                                                        |             | >               |        | 0.000@ 0.0           |            | 0.000@ 0.0    |            | 0.000@ 0.0      |              | 0.000@ 0.0      |                            | 0.000@ 0.0      |  |             |  |
| BRANCH CURRENT (PU) TO                                                   |             | >               |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
| 0 ZIA 1                                                                  |             | 115.            | 1L     | 2.308@ 107.8         | 0.000@ 0.0 |               | 0.000@ 0.0 | 2.308@ 107.8    | 2.308@ -12.2 |                 | 2.308@-132.2               |                 |  |             |  |
| 120 STORIE LAKE                                                          |             | 115.            | 1L     | 1.479@ 103.3         | 0.000@ 0.0 |               | 0.000@ 0.0 | 1.479@ 103.3    | 1.479@ -16.7 |                 | 1.479@-136.7               |                 |  |             |  |
| 174 XFMR VALENCI                                                         |             | 13.8            | 1T     | 0.000@ 0.0           | 0.000@ 0.0 |               | 0.000@ 0.0 | 0.000@ 0.0      | 0.000@ 0.0   |                 | 0.000@ 0.0                 |                 |  |             |  |
| CURRENT TO FAULT (PU)                                                    |             | >               |        | 3.783@ -73.9         |            | 0.000@ 0.0    |            | 0.000@ 0.0      |              | 3.783@ -73.9    |                            | 3.783@ 166.1    |  |             |  |
| THEVENIN IMPEDANCE (PU)                                                  |             | >               |        | 0.26431@ 73.9        |            | 0.26424@ 73.9 |            | 0.29911@ 82.9   |              |                 |                            |                 |  |             |  |
| -----                                                                    |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
| EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU): |             |                 |        |                      |            |               |            |                 |              | PHASE A         |                            | PHASE B         |  | PHASE C     |  |
| CAP FW 345.000kV -                                                       |             |                 |        | RIO_PUERCO 345.000kV |            |               |            | 0.000 + j-0.027 |              | 0.000 + j-0.027 |                            | 0.000 + j-0.027 |  |             |  |
| CAP WW 345.000kV -                                                       |             |                 |        | RIO_PUERCO 345.000kV |            |               |            | 0.000 + j-0.027 |              | 0.000 + j-0.027 |                            | 0.000 + j-0.027 |  |             |  |
| OJO 345.000kV -                                                          |             |                 |        | OJO CAP 345.000kV    |            |               |            | 0.000 + j-0.037 |              | 0.000 + j-0.037 |                            | 0.000 + j-0.037 |  |             |  |
| -----                                                                    |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |
| =====                                                                    |             |                 |        |                      |            |               |            |                 |              |                 |                            |                 |  |             |  |

PAGE 5 Bus Fault on: 66 VALENCIA 115. kV 1LG Type=A

|                                                                           |             |                      |          |                  |      |              |       |            |                            |                 |       |                 |               |               |  |
|---------------------------------------------------------------------------|-------------|----------------------|----------|------------------|------|--------------|-------|------------|----------------------------|-----------------|-------|-----------------|---------------|---------------|--|
| =====                                                                     |             |                      |          |                  |      |              |       |            |                            |                 |       |                 |               |               |  |
| 4. Bus Fault on: 66 VALENCIA 115. kV 1LG Type=A                           |             |                      |          |                  |      |              |       |            |                            |                 |       |                 |               |               |  |
| FAULT CURRENT (PU @ DEG)                                                  |             |                      |          |                  |      |              |       |            |                            |                 |       |                 |               |               |  |
| + SEQ                                                                     |             | - SEQ                |          | 0 SEQ            |      | A PHASE      |       | B PHASE    |                            | C PHASE         |       |                 |               |               |  |
| 1.212@ -77.2                                                              |             | 1.212@ -77.2         |          | 1.212@ -77.2     |      | 3.635@ -77.2 |       | 0.000@ 0.0 |                            | 0.000@ 0.0      |       |                 |               |               |  |
| THEVENIN IMPEDANCE (PU)                                                   |             |                      |          |                  |      |              |       |            |                            |                 |       |                 |               |               |  |
| 0.07308+j0.25401                                                          |             | 0.0731+j0.25392      |          | 0.03684+j0.29683 |      |              |       |            |                            |                 |       |                 |               |               |  |
| SHORT CIRCUIT MVA= 363.5 X/R RATIO= 4.39707 R0/X1= 0.14504 X0/X1= 1.16859 |             |                      |          |                  |      |              |       |            |                            |                 |       |                 |               |               |  |
| -----                                                                     |             |                      |          |                  |      |              |       |            |                            |                 |       |                 |               |               |  |
| BUS                                                                       | 66 VALENCIA | 115.KV               | AREA     | 1                | ZONE | 1            | TIER  | 0          | (PREFault V=1.000@ 0.0 PU) |                 |       |                 |               |               |  |
|                                                                           |             | + SEQ                |          |                  |      | - SEQ        |       | 0 SEQ      |                            | A PHASE         |       | B PHASE         | C PHASE       |               |  |
| VOLTAGE (KV, L-G)                                                         |             | >                    | 45.182@  | 1.5              |      | 21.257@      | 176.8 | 24.063@    | 174.3                      | 0.000@          | 0.0   | 70.877@-120.4   | 64.756@ 123.7 |               |  |
| BRANCH CURRENT (PU) TO                                                    |             | >                    |          |                  |      |              |       |            |                            |                 |       |                 |               |               |  |
| 0 ZIA 1                                                                   |             | 115. 1L              | 0.739@   | 104.6            |      | 0.739@       | 104.6 | 0.306@     | 114.2                      | 1.781@          | 106.2 | 0.440@ -82.1    | 0.440@ -82.1  |               |  |
| 120 STORIE LAKE                                                           |             | 115. 1L              | 0.474@   | 100.1            |      | 0.473@       | 100.1 | 0.373@     | 103.8                      | 1.320@          | 101.1 | 0.104@ -93.3    | 0.104@ -93.4  |               |  |
| 174 XFMR VALENCI                                                          |             | 13.8 1T              | 0.000@   | 0.0              |      | 0.000@       | 0.0   | 0.542@     | 95.7                       | 0.542@          | 95.7  | 0.542@ 95.7     | 0.542@ 95.7   |               |  |
| CURRENT TO FAULT (PU)                                                     |             | >                    | 1.212@   | -77.2            |      | 1.212@       | -77.2 | 1.212@     | -77.2                      | 3.635@          | -77.2 | 0.000@ 0.0      | 0.000@ 0.0    |               |  |
| THEVENIN IMPEDANCE (PU)                                                   |             | >                    | 0.26431@ | 73.9             |      | 0.26424@     | 73.9  | 0.29911@   | 82.9                       |                 |       |                 |               |               |  |
| -----                                                                     |             |                      |          |                  |      |              |       |            |                            |                 |       |                 |               |               |  |
| EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU):  |             |                      |          |                  |      |              |       |            |                            | PHASE A         |       | PHASE B         |               | PHASE C       |  |
| CAP FW 345.000kV -                                                        |             | RIO_PUERCO 345.000kV |          |                  |      |              |       |            |                            | 0.000 + j-0.027 |       | 0.000 + j-0.027 |               | 0.000 + j-0.0 |  |
| CAP WW 345.000kV -                                                        |             | RIO_PUERCO 345.000kV |          |                  |      |              |       |            |                            | 0.000 + j-0.027 |       | 0.000 + j-0.027 |               | 0.000 + j-0.0 |  |
| OJO 345.000kV -                                                           |             | OJO CAP 345.000kV    |          |                  |      |              |       |            |                            | 0.000 + j-0.037 |       | 0.000 + j-0.037 |               | 0.000 + j-0.0 |  |
| =====                                                                     |             |                      |          |                  |      |              |       |            |                            |                 |       |                 |               |               |  |

|                                                                          |                 |                  |                      |                  |               |                            |            |                 |              |                 |            |                 |            |  |
|--------------------------------------------------------------------------|-----------------|------------------|----------------------|------------------|---------------|----------------------------|------------|-----------------|--------------|-----------------|------------|-----------------|------------|--|
| =====                                                                    |                 |                  |                      |                  |               |                            |            |                 |              |                 |            |                 |            |  |
| 5. Bus Fault on: 120 STORIE LAKE 115. kV 3LG                             |                 |                  |                      |                  |               |                            |            |                 |              |                 |            |                 |            |  |
| FAULT CURRENT (PU @ DEG)                                                 |                 |                  |                      |                  |               |                            |            |                 |              |                 |            |                 |            |  |
| + SEQ                                                                    |                 | - SEQ            |                      | 0 SEQ            |               | A PHASE                    |            | B PHASE         |              | C PHASE         |            |                 |            |  |
| 3.668@ -74.2                                                             |                 | 0.000@ 0.0       |                      | 0.000@ 0.0       |               | 3.668@ -74.2               |            | 3.668@ 165.8    |              | 3.668@ 45.8     |            |                 |            |  |
| THEVENIN IMPEDANCE (PU)                                                  |                 |                  |                      |                  |               |                            |            |                 |              |                 |            |                 |            |  |
| 0.07401+j0.26237                                                         |                 | 0.07403+j0.26229 |                      | 0.04866+j0.33513 |               |                            |            |                 |              |                 |            |                 |            |  |
| SHORT CIRCUIT MVA= 366.8 X/R RATIO= 3.54528 R0/X1= 0.18547 X0/X1= 1.2773 |                 |                  |                      |                  |               |                            |            |                 |              |                 |            |                 |            |  |
| -----                                                                    |                 |                  |                      |                  |               |                            |            |                 |              |                 |            |                 |            |  |
| BUS                                                                      | 120 STORIE LAKE | 115.KV           | AREA 1               | ZONE 1           | TIER 0        | (PREFault V=1.000@ 0.0 PU) |            |                 |              |                 |            |                 |            |  |
|                                                                          |                 |                  | + SEQ                |                  | - SEQ         |                            | 0 SEQ      |                 | A PHASE      |                 | B PHASE    |                 | C PHASE    |  |
| VOLTAGE (KV, L-G)                                                        |                 |                  | >                    | 0.000@ 0.0       | 0.000@ 0.0    | 0.000@ 0.0                 | 0.000@ 0.0 | 0.000@ 0.0      | 0.000@ 0.0   | 0.000@ 0.0      | 0.000@ 0.0 | 0.000@ 0.0      | 0.000@ 0.0 |  |
| SHUNT CURRENTS (PU)                                                      |                 |                  | >                    |                  |               |                            |            |                 |              |                 |            |                 |            |  |
| TO SHUNT                                                                 |                 |                  |                      | 0.000@ 0.0       | 0.000@ 0.0    | 0.000@ 0.0                 | 0.000@ 0.0 | 0.000@ 0.0      | 0.000@ 0.0   | 0.000@ 0.0      | 0.000@ 0.0 | 0.000@ 0.0      | 0.000@ 0.0 |  |
| BRANCH CURRENT (PU) TO                                                   |                 |                  | >                    |                  |               |                            |            |                 |              |                 |            |                 |            |  |
| 66 VALENCIA 115. 1L                                                      |                 |                  |                      | 2.080@ 107.9     | 0.000@ 0.0    | 0.000@ 0.0                 | 0.000@ 0.0 | 2.080@ 107.9    | 2.080@ -12.1 | 2.080@ -132.1   |            |                 |            |  |
| 118 SPRINGER 115. 1L                                                     |                 |                  |                      | 1.592@ 102.9     | 0.000@ 0.0    | 0.000@ 0.0                 | 0.000@ 0.0 | 1.592@ 102.9    | 1.592@ -17.1 | 1.592@ -137.1   |            |                 |            |  |
| CURRENT TO FAULT (PU)                                                    |                 |                  | >                    | 3.668@ -74.2     | 0.000@ 0.0    | 0.000@ 0.0                 | 0.000@ 0.0 | 3.668@ -74.2    | 3.668@ 165.8 | 3.668@ 45.8     |            |                 |            |  |
| THEVENIN IMPEDANCE (PU)                                                  |                 |                  | >                    | 0.27261@ 74.2    | 0.27254@ 74.2 | 0.33864@ 81.7              |            |                 |              |                 |            |                 |            |  |
| -----                                                                    |                 |                  |                      |                  |               |                            |            |                 |              |                 |            |                 |            |  |
| EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU): |                 |                  |                      |                  |               |                            |            |                 | PHASE A      |                 | PHASE B    |                 | PHASE C    |  |
| CAP FW 345.000kV -                                                       |                 |                  | RIO_PUERCO 345.000kV |                  |               |                            |            | 0.000 + j-0.027 |              | 0.000 + j-0.027 |            | 0.000 + j-0.027 |            |  |
| CAP WW 345.000kV -                                                       |                 |                  | RIO_PUERCO 345.000kV |                  |               |                            |            | 0.000 + j-0.027 |              | 0.000 + j-0.027 |            | 0.000 + j-0.027 |            |  |
| OJO 345.000kV -                                                          |                 |                  | OJO CAP 345.000kV    |                  |               |                            |            | 0.000 + j-0.037 |              | 0.000 + j-0.037 |            | 0.000 + j-0.037 |            |  |
| -----                                                                    |                 |                  |                      |                  |               |                            |            |                 |              |                 |            |                 |            |  |
| =====                                                                    |                 |                  |                      |                  |               |                            |            |                 |              |                 |            |                 |            |  |

PAGE 7 Bus Fault on: 120 STORIE LAKE 115. kV 1LG Type=A

|                                                                          |                 |                      |          |                   |          |                            |          |                 |        |                 |         |                 |         |       |
|--------------------------------------------------------------------------|-----------------|----------------------|----------|-------------------|----------|----------------------------|----------|-----------------|--------|-----------------|---------|-----------------|---------|-------|
| 6. Bus Fault on: 120 STORIE LAKE 115. kV 1LG Type=A                      |                 |                      |          |                   |          |                            |          |                 |        |                 |         |                 |         |       |
| FAULT CURRENT (PU @ DEG)                                                 |                 |                      |          |                   |          |                            |          |                 |        |                 |         |                 |         |       |
| + SEQ                                                                    |                 | - SEQ                |          | 0 SEQ             |          | A PHASE                    |          | B PHASE         |        | C PHASE         |         |                 |         |       |
| 1.134@ -77.1                                                             |                 | 1.134@ -77.1         |          | 1.134@ -77.1      |          | 3.401@ -77.1               |          | 0.000@ 0.0      |        | 0.000@ 0.0      |         |                 |         |       |
| THEVENIN IMPEDANCE (PU)                                                  |                 |                      |          |                   |          |                            |          |                 |        |                 |         |                 |         |       |
| 0.07401+j0.26237                                                         |                 | 0.07403+j0.26229     |          | 0.04866+j0.33513  |          |                            |          |                 |        |                 |         |                 |         |       |
| SHORT CIRCUIT MVA= 340.1                                                 |                 |                      |          | X/R RATIO= 4.3711 |          | R0/X1= 0.18547             |          | X0/X1= 1.2773   |        |                 |         |                 |         |       |
|                                                                          |                 |                      |          |                   |          |                            |          |                 |        |                 |         |                 |         |       |
| BUS                                                                      | 120 STORIE LAKE | 115.KV               | AREA 1   | ZONE 1            | TIER 0   | (PREFault V=1.000@ 0.0 PU) |          |                 |        |                 |         |                 |         |       |
|                                                                          |                 | + SEQ                |          | - SEQ             |          | 0 SEQ                      |          | A PHASE         |        | B PHASE         |         | C PHASE         |         |       |
| VOLTAGE (KV, L-G)                                                        |                 | >                    | 45.911@  | 1.3               | 20.516@  | 177.1                      | 25.492@  | 175.4           | 0.000@ | 0.0             | 71.572@ | -122.2          | 66.432@ | 125.0 |
| SHUNT CURRENTS (PU)                                                      |                 | >                    |          |                   |          |                            |          |                 |        |                 |         |                 |         |       |
| TO SHUNT                                                                 |                 |                      | 0.000@   | 0.0               | 0.000@   | 0.0                        | 0.235@   | 94.6            | 0.235@ | 94.6            | 0.235@  | 94.6            | 0.235@  | 94.6  |
| BRANCH CURRENT (PU) TO                                                   |                 | >                    |          |                   |          |                            |          |                 |        |                 |         |                 |         |       |
| 66 VALENCIA 115. 1L                                                      |                 |                      | 0.643@   | 105.1             | 0.643@   | 105.1                      | 0.674@   | 104.3           | 1.959@ | 104.8           | 0.032@  | 88.4            | 0.032@  | 88.2  |
| 118 SPRINGER 115. 1L                                                     |                 |                      | 0.492@   | 100.0             | 0.492@   | 100.0                      | 0.228@   | 107.3           | 1.211@ | 101.4           | 0.267@  | -86.1           | 0.267@  | -86.2 |
| CURRENT TO FAULT (PU)                                                    |                 | >                    | 1.134@   | -77.1             | 1.134@   | -77.1                      | 1.134@   | -77.1           | 3.401@ | -77.1           | 0.000@  | 0.0             | 0.000@  | 0.0   |
| THEVENIN IMPEDANCE (PU)                                                  |                 | >                    | 0.27261@ | 74.2              | 0.27254@ | 74.2                       | 0.33864@ | 81.7            |        |                 |         |                 |         |       |
|                                                                          |                 |                      |          |                   |          |                            |          |                 |        |                 |         |                 |         |       |
| EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU): |                 |                      |          |                   |          |                            |          |                 |        |                 |         |                 |         |       |
| CAP FW 345.000kV -                                                       |                 | RIO_PUERCO 345.000kV |          |                   |          |                            |          | PHASE A         |        | PHASE B         |         | PHASE C         |         |       |
|                                                                          |                 |                      |          |                   |          |                            |          | 0.000 + j-0.027 |        | 0.000 + j-0.027 |         | 0.000 + j-0.027 |         |       |
| CAP WW 345.000kV -                                                       |                 | RIO_PUERCO 345.000kV |          |                   |          |                            |          | 0.000 + j-0.027 |        | 0.000 + j-0.027 |         | 0.000 + j-0.027 |         |       |
|                                                                          |                 |                      |          |                   |          |                            |          | 0.000 + j-0.037 |        | 0.000 + j-0.037 |         | 0.000 + j-0.037 |         |       |
| OJO 345.000kV -                                                          |                 | OJO CAP 345.000kV    |          |                   |          |                            |          |                 |        |                 |         |                 |         |       |
|                                                                          |                 |                      |          |                   |          |                            |          |                 |        |                 |         |                 |         |       |



---

## Post Project (Mora Line Project) Short Circuit – Analysis

Confidential: Sean Black (ID 68709) | sblack2@ameren.com | Ameren on 2019-03-05

Lucky Corridor Project In Service

-- ASPEN OneLiner(Tm) --  
VERSION 14.4

DATE AND TIME: Sun Dec 18 20:53:56 2016

OLR FILE NAME: D:\BREAKER-TPL-FAC002\2016TPL-BASE LATE-VERDE -LUCKY.OLR

STUDY DATE: None

NAME OF THIS FILE: D:\BREAKER-TPL-FAC002\REPORTS\LuckyCorridor In.TXT

BASE MVA = 100.

THIS FILE HAS: 444 BUSES  
67 GENERATORS  
0 LOADS  
43 SHUNTS  
326 LINES  
101 2-WINDING TRANSFORMERS  
54 3-WINDING TRANSFORMERS  
2 PHASE SHIFTERS  
16 SWITCHES  
4 SERIES CAPCITORS. 0 BYPASSED  
3 SERIES REACTORS. 3 BYPASSED  
8 MUTUAL COUPLING PAIRS

FILE COMMENTS:..... 2013 Q4 modified as below.....  
w.....

Added Britton sw sta on AW line, Snow Vista on PW line and Scenic on CE line  
Added annotated comment for OOS facilities  
Added Lajara 115kv line to Algodones and associate 69kv TRIS loop  
Added El Cerro, Manzano and Palace Taps on AT line

\_\_\_\_\_ 2014 Q1 MODIFICATIONS \_\_\_\_\_

Added Jicarilla station on OJ 345kV line  
Added Ojo 300MVA auto ISD 2014 (OOS)  
Added Freeport Mining Facilites-MD1 area  
Revised HLM transformer Z

xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx 2014 Q2 MODIFICATIONS xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx  
xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx  
Added Richmond Station, tied to Prager, North and Sandia, via PN, EB-CG-HW line  
sections. Left OOS  
Removed Bus Tie Reactor at WM1-2, replaced with switch N.C.

-----2015 FUT MODIFICATIONS -----  
-----

Bussed 345kV line into Rio Puerco  
Adder PR line Progress-Rio Puerco 115kV

PREFault VOLTAGE PROFILE: FLAT BUS VOLTAGES. PREFault V=1 PU  
GENERATOR IMPEDANCE: SUBTRANSIENT

IGNORE PHASE SHIFT [ ]  
IGNORE LOADS [ ]

|                                             |     |
|---------------------------------------------|-----|
| IGNORE TRANSMISSION LINE G+jB               | [ ] |
| IGNORE SHUNTS WITH + SEQ IMPEDANCE          | [ ] |
| IGNORE TRANSFORMER LINE SHUNTS              | [ ] |
| MOV ITERATION                               | [X] |
| GENERATOR CURRENT LIMIT                     | [ ] |
| SIMULATE VOLTAGE CONTROLLED CURRENT SOURCES | [ ] |

=====

Confidential: Sean Black (ID 68709) | sblack2@ameren.com | Ameren on 2019-03-05

PAGE 2 Bus Fault on: 0 ZIA 1 115. kV 3LG

|                                                                          |         |                      |              |                          |        |                            |  |                 |              |                 |  |                 |  |
|--------------------------------------------------------------------------|---------|----------------------|--------------|--------------------------|--------|----------------------------|--|-----------------|--------------|-----------------|--|-----------------|--|
| =====                                                                    |         |                      |              |                          |        |                            |  |                 |              |                 |  |                 |  |
| 1. Bus Fault on:                                                         |         | 0 ZIA 1              |              | 115. kV 3LG              |        |                            |  |                 |              |                 |  |                 |  |
|                                                                          |         |                      |              | FAULT CURRENT (PU @ DEG) |        |                            |  |                 |              |                 |  |                 |  |
| + SEQ                                                                    |         | - SEQ                |              | 0 SEQ                    |        | A PHASE                    |  | B PHASE         |              | C PHASE         |  |                 |  |
| 19.427@ -80.3                                                            |         | 0.000@ 0.0           |              | 0.000@ 0.0               |        | 19.427@ -80.3              |  | 19.427@ 159.7   |              | 19.427@ 39.7    |  |                 |  |
|                                                                          |         |                      |              | THEVENIN IMPEDANCE (PU)  |        |                            |  |                 |              |                 |  |                 |  |
| 0.00864+j0.05074                                                         |         | 0.00864+j0.05062     |              | 0.00814+j0.05427         |        |                            |  |                 |              |                 |  |                 |  |
| =====                                                                    |         |                      |              |                          |        |                            |  |                 |              |                 |  |                 |  |
| SHORT CIRCUIT MVA= 1942.7                                                |         |                      |              | X/R RATIO= 5.86994       |        |                            |  | R0/X1= 0.16038  |              | X0/X1= 1.06954  |  |                 |  |
| =====                                                                    |         |                      |              |                          |        |                            |  |                 |              |                 |  |                 |  |
| BUS                                                                      | 0 ZIA 1 | 115.KV               | AREA 1       | ZONE 1                   | TIER 0 | (PREFault V=1.000@ 0.0 PU) |  |                 |              |                 |  |                 |  |
|                                                                          |         | + SEQ                |              | - SEQ                    |        | 0 SEQ                      |  | A PHASE         |              | B PHASE         |  | C PHASE         |  |
| VOLTAGE (KV, L-G)                                                        |         | > 0.000@ 0.0         |              | 0.000@ 0.0               |        | 0.000@ 0.0                 |  | 0.000@ 0.0      |              | 0.000@ 0.0      |  | 0.000@ 0.0      |  |
| BRANCH CURRENT (PU) TO                                                   |         | >                    |              |                          |        |                            |  |                 |              |                 |  |                 |  |
| 0 ANZ TP                                                                 |         | 115. 1L              | 7.834@ 100.2 | 0.000@ 0.0               |        | 0.000@ 0.0                 |  | 7.834@ 100.2    | 7.834@ -19.8 | 7.834@ -139.8   |  |                 |  |
| 66 VALENCIA                                                              |         | 115. 1L              | 1.183@ 104.8 | 0.000@ 0.0               |        | 0.000@ 0.0                 |  | 1.183@ 104.8    | 1.183@ -15.2 | 1.183@ -135.2   |  |                 |  |
| 7 B-A                                                                    |         | 115. 1L              | 3.521@ 102.8 | 0.000@ 0.0               |        | 0.000@ 0.0                 |  | 3.521@ 102.8    | 3.521@ -17.2 | 3.521@ -137.2   |  |                 |  |
| 0 ZIA 2                                                                  |         | 46. X                | 0.000@ 0.0   | 0.000@ 0.0               |        | 0.000@ 0.0                 |  | 0.000@ 0.0      | 0.000@ 0.0   | 0.000@ 0.0      |  |                 |  |
| 0 Z3TERT                                                                 |         | 13.8 X               |              |                          |        |                            |  |                 |              |                 |  |                 |  |
| AUTO NEUTRAL CURRENT =                                                   |         |                      |              | 0.0 @ 112.6 A            |        |                            |  |                 |              |                 |  |                 |  |
| 73 ZIA 2                                                                 |         | 115. S               | 6.910@ 96.6  | 0.000@ 0.0               |        | 0.000@ 0.0                 |  | 6.910@ 96.6     | 6.910@ -23.4 | 6.910@ -143.4   |  |                 |  |
| 190 ZIA XFMR 1                                                           |         | 7.2 1T               | 0.000@ 0.0   | 0.000@ 0.0               |        | 0.000@ 0.0                 |  | 0.000@ 0.0      | 0.000@ 0.0   | 0.000@ 0.0      |  |                 |  |
| 191 ZIA XFMR 2                                                           |         | 7.2 1T               | 0.000@ 0.0   | 0.000@ 0.0               |        | 0.000@ 0.0                 |  | 0.000@ 0.0      | 0.000@ 0.0   | 0.000@ 0.0      |  |                 |  |
| =====                                                                    |         |                      |              |                          |        |                            |  |                 |              |                 |  |                 |  |
| CURRENT TO FAULT (PU)                                                    |         | > 19.427@ -80.3      |              | 0.000@ 0.0               |        | 0.000@ 0.0                 |  | 19.427@ 80.3    |              | 19.427@ 159.7   |  | 19.427@ 39.7    |  |
| THEVENIN IMPEDANCE (PU)                                                  |         | > 0.05148@ 80.3      |              | 0.05136@ 80.3            |        | 0.05488@ 81.5              |  |                 |              |                 |  |                 |  |
| =====                                                                    |         |                      |              |                          |        |                            |  |                 |              |                 |  |                 |  |
| EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU): |         |                      |              |                          |        |                            |  | PHASE A         |              | PHASE B         |  | PHASE C         |  |
| CAP FW 345.000kV -                                                       |         | RIO_PUERCO 345.000kV |              |                          |        |                            |  | 0.000 + j-0.027 |              | 0.000 + j-0.027 |  | 0.000 + j-0.027 |  |
| CAP WW 345.000kV -                                                       |         | RIO_PUERCO 345.000kV |              |                          |        |                            |  | 0.000 + j-0.027 |              | 0.000 + j-0.027 |  | 0.000 + j-0.027 |  |
| OJO 345.000kV -                                                          |         | OJO CAP 345.000kV    |              |                          |        |                            |  | 0.000 + j-0.037 |              | 0.000 + j-0.037 |  | 0.000 + j-0.037 |  |
| =====                                                                    |         |                      |              |                          |        |                            |  |                 |              |                 |  |                 |  |

PAGE 3

Bus Fault on:

0 ZIA 1

115. kV 1LG Type=A

```

=====
2. Bus Fault on:          0 ZIA 1          115. kV 1LG Type=A
                          FAULT CURRENT (PU @ DEG)
                          + SEQ          - SEQ          0 SEQ          A PHASE          B PHASE          C PHASE
                          6.341@ -80.7      6.341@ -80.7      6.341@ -80.7      19.023@ -80.7      0.000@ 0.0      0.000@ 0.0
                          THEVENIN IMPEDANCE (PU)
                          0.00864+j0.05074  0.00864+j0.05062  0.00814+j0.05427

                          SHORT CIRCUIT MVA= 1902.3          X/R RATIO= 6.12178          R0/X1= 0.16038          X0/X1= 1.06954
-----
BUS          0 ZIA 1          115.KV AREA 1 ZONE 1 TIER 0          (PREFault V=1.000@ 0.0 PU)
                          + SEQ          - SEQ          0 SEQ          A PHASE          B PHASE          C PHASE
VOLTAGE (KV, L-G)          >          44.724@ 0.2          21.622@ 179.6          23.105@ -179.3          0.000@ 0.0          67.490@ -120.9          66.708@ 121.3
BRANCH CURRENT (PU) TO          >
0 ANZ TP          115. 1L          2.557@ 99.8          2.557@ 99.8          1.767@ 102.3          6.880@ 100.5          0.795@ -85.7          0.795@ -85.7
66 VALENCIA          115. 1L          0.386@ 104.4          0.385@ 104.4          0.238@ 106.4          1.009@ 104.9          0.148@ -78.6          0.148@ -79.0
7 B-A          115. 1L          1.149@ 102.4          1.149@ 102.4          0.483@ 108.1          2.780@ 103.4          0.670@ -81.7          0.670@ -81.7
0 ZIA 2          46. X          0.000@ 0.0          0.000@ 0.0          0.995@ 90.7          0.995@ 90.7          0.995@ 90.7          0.995@ 90.7
0 Z3TERT          13.8 X
AUTO NEUTRAL CURRENT =          1499.2 @ 90.7 A
73 ZIA 2          115. S          2.256@ 96.2          2.256@ 96.2          1.811@ 102.6          6.314@ 98.0          0.498@ -107.5          0.498@ -107.4
190 ZIA XFMR 1          7.2 1T          0.000@ 0.0          0.000@ 0.0          0.576@ 91.2          0.576@ 91.2          0.576@ 91.2          0.576@ 91.2
191 ZIA XFMR 2          7.2 1T          0.000@ 0.0          0.000@ 0.0          0.505@ 91.3          0.505@ 91.3          0.505@ 91.3          0.505@ 91.3

CURRENT TO FAULT (PU)          >          6.341@ -80.7          6.341@ -80.7          6.341@ -80.7          19.023@ -80.7          0.000@ 0.0          0.000@ 0.0
THEVENIN IMPEDANCE (PU)          >          0.05148@ 80.3          0.05136@ 80.3          0.05488@ 81.5

EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU):
CAP FW 345.000kV - RIO_PUERCO 345.000kV          0.000 + j-0.027          0.000 + j-0.027          0.000 + j-0.027
CAP WW 345.000kV - RIO_PUERCO 345.000kV          0.000 + j-0.027          0.000 + j-0.027          0.000 + j-0.027
OJO 345.000kV - OJO CAP 345.000kV          0.000 + j-0.037          0.000 + j-0.037          0.000 + j-0.037
=====

```

PAGE 4 Bus Fault on: 66 VALENCIA 115. kV 3LG

|                                                                          |             |        |                    |    |                  |            |                |            |                            |              |                 |              |                 |              |             |  |
|--------------------------------------------------------------------------|-------------|--------|--------------------|----|------------------|------------|----------------|------------|----------------------------|--------------|-----------------|--------------|-----------------|--------------|-------------|--|
| =====                                                                    |             |        |                    |    |                  |            |                |            |                            |              |                 |              |                 |              |             |  |
| 3. Bus Fault on:                                                         |             |        | 66 VALENCIA        |    | 115. kV 3LG      |            |                |            |                            |              |                 |              |                 |              |             |  |
| FAULT CURRENT (PU @ DEG)                                                 |             |        |                    |    |                  |            |                |            |                            |              |                 |              |                 |              |             |  |
| + SEQ                                                                    |             |        | - SEQ              |    | 0 SEQ            |            | A PHASE        |            | B PHASE                    |              | C PHASE         |              |                 |              |             |  |
| 4.809@ -75.6                                                             |             |        | 0.000@ 0.0         |    | 0.000@ 0.0       |            | 4.809@ -75.6   |            | 4.809@ 164.4               |              | 4.809@ 44.4     |              |                 |              |             |  |
| THEVENIN IMPEDANCE (PU)                                                  |             |        |                    |    |                  |            |                |            |                            |              |                 |              |                 |              |             |  |
| 0.05154+j0.20146                                                         |             |        | 0.05157+j 0.2014   |    | 0.03606+j0.26389 |            |                |            |                            |              |                 |              |                 |              |             |  |
| -----                                                                    |             |        |                    |    |                  |            |                |            |                            |              |                 |              |                 |              |             |  |
| SHORT CIRCUIT MVA= 480.9                                                 |             |        | X/R RATIO= 3.90861 |    | R0/X1= 0.17898   |            | X0/X1= 1.30988 |            |                            |              |                 |              |                 |              |             |  |
| -----                                                                    |             |        |                    |    |                  |            |                |            |                            |              |                 |              |                 |              |             |  |
| BUS                                                                      | 66 VALENCIA | 115.KV | AREA               | 1  | ZONE             | 1          | TIER           | 0          | (PREFault V=1.000@ 0.0 PU) |              |                 |              |                 |              |             |  |
|                                                                          |             |        | + SEQ              |    | - SEQ            |            | 0 SEQ          |            | A PHASE                    |              | B PHASE         |              | C PHASE         |              |             |  |
| VOLTAGE (KV, L-G)                                                        |             |        | >                  |    | 0.000@ 0.0       |            | 0.000@ 0.0     |            | 0.000@ 0.0                 |              | 0.000@ 0.0      |              | 0.000@ 0.0      |              |             |  |
| BRANCH CURRENT (PU) TO                                                   |             |        | >                  |    |                  |            |                |            |                            |              |                 |              |                 |              |             |  |
| 0 ZIA 1                                                                  |             |        | 115.               | 1L | 2.302@ 107.8     | 0.000@ 0.0 |                | 0.000@ 0.0 |                            | 2.302@ 107.8 |                 | 2.302@ -12.2 |                 | 2.302@-132.2 |             |  |
| 120 STORIE LAKE                                                          |             |        | 115.               | 1L | 2.515@ 101.2     | 0.000@ 0.0 |                | 0.000@ 0.0 |                            | 2.515@ 101.2 |                 | 2.515@ -18.8 |                 | 2.515@-138.8 |             |  |
| 174 XFMR VALENCI                                                         |             |        | 13.8               | 1T | 0.000@ 0.0       | 0.000@ 0.0 |                | 0.000@ 0.0 |                            | 0.000@ 0.0   |                 | 0.000@ 0.0   |                 | 0.000@ 0.0   |             |  |
| CURRENT TO FAULT (PU)                                                    |             |        | >                  |    | 4.809@ -75.6     |            | 0.000@ 0.0     |            | 0.000@ 0.0                 |              | 4.809@ -75.6    |              | 4.809@ 164.4    |              | 4.809@ 44.4 |  |
| THEVENIN IMPEDANCE (PU)                                                  |             |        | >                  |    | 0.20795@ 75.6    |            | 0.2079@ 75.6   |            | 0.26634@ 82.2              |              |                 |              |                 |              |             |  |
| -----                                                                    |             |        |                    |    |                  |            |                |            |                            |              |                 |              |                 |              |             |  |
| EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU): |             |        |                    |    |                  |            |                |            | PHASE A                    |              | PHASE B         |              | PHASE C         |              |             |  |
| CAP FW 345.000kV - RIO_PUERCO 345.000kV                                  |             |        |                    |    |                  |            |                |            | 0.000 + j-0.027            |              | 0.000 + j-0.027 |              | 0.000 + j-0.027 |              |             |  |
| CAP WW 345.000kV - RIO_PUERCO 345.000kV                                  |             |        |                    |    |                  |            |                |            | 0.000 + j-0.027            |              | 0.000 + j-0.027 |              | 0.000 + j-0.027 |              |             |  |
| OJO 345.000kV - OJO CAP 345.000kV                                        |             |        |                    |    |                  |            |                |            | 0.000 + j-0.037            |              | 0.000 + j-0.037 |              | 0.000 + j-0.037 |              |             |  |
| -----                                                                    |             |        |                    |    |                  |            |                |            |                            |              |                 |              |                 |              |             |  |
| =====                                                                    |             |        |                    |    |                  |            |                |            |                            |              |                 |              |                 |              |             |  |

PAGE 5 Bus Fault on: 66 VALENCIA 115. kV 1LG Type=A

|                                                                           |             |                      |              |                  |              |              |              |                 |                            |                 |               |
|---------------------------------------------------------------------------|-------------|----------------------|--------------|------------------|--------------|--------------|--------------|-----------------|----------------------------|-----------------|---------------|
| =====                                                                     |             |                      |              |                  |              |              |              |                 |                            |                 |               |
| 4. Bus Fault on: 66 VALENCIA 115. kV 1LG Type=A                           |             |                      |              |                  |              |              |              |                 |                            |                 |               |
| FAULT CURRENT (PU @ DEG)                                                  |             |                      |              |                  |              |              |              |                 |                            |                 |               |
| + SEQ                                                                     |             | - SEQ                |              | 0 SEQ            |              | A PHASE      |              | B PHASE         |                            | C PHASE         |               |
| 1.468@ -78.2                                                              |             | 1.468@ -78.2         |              | 1.468@ -78.2     |              | 4.405@ -78.2 |              | 0.000@ 0.0      |                            | 0.000@ 0.0      |               |
| THEVENIN IMPEDANCE (PU)                                                   |             |                      |              |                  |              |              |              |                 |                            |                 |               |
| 0.05154+j0.20146                                                          |             | 0.05157+j 0.2014     |              | 0.03606+j0.26389 |              |              |              |                 |                            |                 |               |
| SHORT CIRCUIT MVA= 440.5 X/R RATIO= 4.79094 R0/X1= 0.17898 X0/X1= 1.30988 |             |                      |              |                  |              |              |              |                 |                            |                 |               |
| -----                                                                     |             |                      |              |                  |              |              |              |                 |                            |                 |               |
| BUS                                                                       | 66 VALENCIA | 115.KV               | AREA         | 1                | ZONE         | 1            | TIER         | 0               | (PREFault V=1.000@ 0.0 PU) |                 |               |
|                                                                           |             | + SEQ                |              | - SEQ            |              | 0 SEQ        |              | A PHASE         |                            | B PHASE         | C PHASE       |
| VOLTAGE (KV, L-G)                                                         |             | >                    | 46.154@      | 1.1              | 20.266@      | 177.4        | 25.963@      | 176.0           | 0.000@ 0.0                 | 71.664@-122.8   | 67.149@ 125.3 |
| BRANCH CURRENT (PU) TO                                                    |             | >                    |              |                  |              |              |              |                 |                            |                 |               |
| 0 ZIA 1                                                                   |             | 115. 1L              | 0.703@       | 105.3            | 0.703@       | 105.3        | 0.331@       | 112.5           | 1.734@                     | 106.6           | 0.377@ -81.1  |
| 120 STORIE LAKE                                                           |             | 115. 1L              | 0.768@       | 98.6             | 0.768@       | 98.6         | 0.564@       | 103.6           | 2.098@                     | 100.0           | 0.212@ -94.8  |
| 174 XFMR VALENCI                                                          |             | 13.8 1T              | 0.000@       | 0.0              | 0.000@       | 0.0          | 0.585@       | 94.0            | 0.585@                     | 94.0            | 0.585@ 94.0   |
| CURRENT TO FAULT (PU)                                                     |             | >                    | 1.468@ -78.2 |                  | 1.468@ -78.2 |              | 1.468@ -78.2 |                 | 4.405@ -78.2               | 0.000@ 0.0      | 0.000@ 0.0    |
| THEVENIN IMPEDANCE (PU)                                                   |             | >                    | 0.20795@     | 75.6             | 0.2079@      | 75.6         | 0.26634@     | 82.2            |                            |                 |               |
| -----                                                                     |             |                      |              |                  |              |              |              |                 |                            |                 |               |
| EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU):  |             |                      |              |                  |              |              |              |                 |                            |                 |               |
| CAP FW 345.000kV -                                                        |             | RIO_PUERCO 345.000kV |              |                  |              |              |              | PHASE A         |                            | PHASE B         | PHASE C       |
|                                                                           |             |                      |              |                  |              |              |              | 0.000 + j-0.027 |                            | 0.000 + j-0.027 | 0.000 + j-0.0 |
| CAP WW 345.000kV -                                                        |             | RIO_PUERCO 345.000kV |              |                  |              |              |              | 0.000 + j-0.027 |                            | 0.000 + j-0.027 | 0.000 + j-0.0 |
|                                                                           |             |                      |              |                  |              |              |              | 0.000 + j-0.037 |                            | 0.000 + j-0.037 | 0.000 + j-0.0 |
| OJO 345.000kV -                                                           |             | OJO CAP 345.000kV    |              |                  |              |              |              |                 |                            |                 |               |
| =====                                                                     |             |                      |              |                  |              |              |              |                 |                            |                 |               |

|                                                                                                  |  |  |  |  |  |  |  |  |  |  |  |  |
|--------------------------------------------------------------------------------------------------|--|--|--|--|--|--|--|--|--|--|--|--|
| =====                                                                                            |  |  |  |  |  |  |  |  |  |  |  |  |
| 5. Bus Fault on: 120 STORIE LAKE 115. kV 3LG                                                     |  |  |  |  |  |  |  |  |  |  |  |  |
| FAULT CURRENT (PU @ DEG)                                                                         |  |  |  |  |  |  |  |  |  |  |  |  |
| + SEQ - SEQ 0 SEQ A PHASE B PHASE C PHASE                                                        |  |  |  |  |  |  |  |  |  |  |  |  |
| 4.914@ -76.6 0.000@ 0.0 0.000@ 0.0 4.914@ -76.6 4.914@ 163.4 4.914@ 43.4                         |  |  |  |  |  |  |  |  |  |  |  |  |
| THEVENIN IMPEDANCE (PU)                                                                          |  |  |  |  |  |  |  |  |  |  |  |  |
| 0.04725+j0.19794 0.04728+j0.19788 0.04131+j0.27833                                               |  |  |  |  |  |  |  |  |  |  |  |  |
| SHORT CIRCUIT MVA= 491.4 X/R RATIO= 4.18958 R0/X1= 0.2087 X0/X1= 1.40617                         |  |  |  |  |  |  |  |  |  |  |  |  |
| -----                                                                                            |  |  |  |  |  |  |  |  |  |  |  |  |
| BUS 120 STORIE LAKE 115.KV AREA 1 ZONE 1 TIER 0 (PREFault V=1.000@ 0.0 PU)                       |  |  |  |  |  |  |  |  |  |  |  |  |
| + SEQ - SEQ 0 SEQ A PHASE B PHASE C PHASE                                                        |  |  |  |  |  |  |  |  |  |  |  |  |
| VOLTAGE (KV, L-G) > 0.000@ 0.0 0.000@ 0.0 0.000@ 0.0 0.000@ 0.0 0.000@ 0.0 0.000@ 0.0            |  |  |  |  |  |  |  |  |  |  |  |  |
| SHUNT CURRENTS (PU) > 0.000@ 0.0 0.000@ 0.0 0.000@ 0.0 0.000@ 0.0 0.000@ 0.0 0.000@ 0.0          |  |  |  |  |  |  |  |  |  |  |  |  |
| TO SHUNT                                                                                         |  |  |  |  |  |  |  |  |  |  |  |  |
| BRANCH CURRENT (PU) TO >                                                                         |  |  |  |  |  |  |  |  |  |  |  |  |
| 118 SPRINGER 115. 2L 1.501@ 96.6 0.000@ 0.0 0.000@ 0.0 1.501@ 96.6 1.501@ -23.4 1.501@-143.4     |  |  |  |  |  |  |  |  |  |  |  |  |
| 66 VALENCIA 115. 1L 2.073@ 108.0 0.000@ 0.0 0.000@ 0.0 2.073@ 108.0 2.073@ -12.0 2.073@-132.0    |  |  |  |  |  |  |  |  |  |  |  |  |
| 118 SPRINGER 115. 1L 1.357@ 104.0 0.000@ 0.0 0.000@ 0.0 1.357@ 104.0 1.357@ -16.0 1.357@-136.0   |  |  |  |  |  |  |  |  |  |  |  |  |
| CURRENT TO FAULT (PU) > 4.914@ -76.6 0.000@ 0.0 0.000@ 0.0 4.914@ -76.6 4.914@ 163.4 4.914@ 43.4 |  |  |  |  |  |  |  |  |  |  |  |  |
| THEVENIN IMPEDANCE (PU) > 0.2035@ 76.6 0.20345@ 76.6 0.28138@ 81.6                               |  |  |  |  |  |  |  |  |  |  |  |  |
| -----                                                                                            |  |  |  |  |  |  |  |  |  |  |  |  |
| EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU):                         |  |  |  |  |  |  |  |  |  |  |  |  |
| CAP FW 345.000kV - RIO_PUERCO 345.000kV PHASE A PHASE B PHASE C                                  |  |  |  |  |  |  |  |  |  |  |  |  |
| CAP WW 345.000kV - RIO_PUERCO 345.000kV 0.000 + j-0.027 0.000 + j-0.027 0.000 + j-0.027          |  |  |  |  |  |  |  |  |  |  |  |  |
| OJO 345.000kV - OJO CAP 345.000kV 0.000 + j-0.027 0.000 + j-0.027 0.000 + j-0.027                |  |  |  |  |  |  |  |  |  |  |  |  |
| 0.000 + j-0.037 0.000 + j-0.037 0.000 + j-0.037                                                  |  |  |  |  |  |  |  |  |  |  |  |  |
| -----                                                                                            |  |  |  |  |  |  |  |  |  |  |  |  |
| =====                                                                                            |  |  |  |  |  |  |  |  |  |  |  |  |

PAGE 7 Bus Fault on: 120 STORIE LAKE 115. kV 1LG Type=A


|                                                                                                      |  |  |  |  |  |  |  |  |  |  |  |
|------------------------------------------------------------------------------------------------------|--|--|--|--|--|--|--|--|--|--|--|
| =====                                                                                                |  |  |  |  |  |  |  |  |  |  |  |
| 6. Bus Fault on: 120 STORIE LAKE 115. kV 1LG Type=A                                                  |  |  |  |  |  |  |  |  |  |  |  |
| FAULT CURRENT (PU @ DEG)                                                                             |  |  |  |  |  |  |  |  |  |  |  |
| + SEQ - SEQ 0 SEQ A PHASE B PHASE C PHASE                                                            |  |  |  |  |  |  |  |  |  |  |  |
| 1.454@ -78.6 1.454@ -78.6 1.454@ -78.6 4.362@ -78.6 0.000@ 0.0 0.000@ 0.0                            |  |  |  |  |  |  |  |  |  |  |  |
| THEVENIN IMPEDANCE (PU)                                                                              |  |  |  |  |  |  |  |  |  |  |  |
| 0.04725+j0.19794 0.04728+j0.19788 0.04131+j0.27833                                                   |  |  |  |  |  |  |  |  |  |  |  |
| SHORT CIRCUIT MVA= 436.2 X/R RATIO= 4.96318 R0/X1= 0.2087 X0/X1= 1.40617                             |  |  |  |  |  |  |  |  |  |  |  |
| -----                                                                                                |  |  |  |  |  |  |  |  |  |  |  |
| BUS 120 STORIE LAKE 115.KV AREA 1 ZONE 1 TIER 0 (PREFault V=1.000@ 0.0 PU)                           |  |  |  |  |  |  |  |  |  |  |  |
| + SEQ - SEQ 0 SEQ A PHASE B PHASE C PHASE                                                            |  |  |  |  |  |  |  |  |  |  |  |
| VOLTAGE (KV, L-G) > 46.766@ 0.9 19.643@ 178.0 27.166@ -177.1 0.000@ 0.0 72.165@ -124.3 68.738@ 126.3 |  |  |  |  |  |  |  |  |  |  |  |
| SHUNT CURRENTS (PU) >                                                                                |  |  |  |  |  |  |  |  |  |  |  |
| TO SHUNT 0.000@ 0.0 0.000@ 0.0 0.251@ 92.9 0.251@ 92.9 0.251@ 92.9 0.251@ 92.9                       |  |  |  |  |  |  |  |  |  |  |  |
| BRANCH CURRENT (PU) TO >                                                                             |  |  |  |  |  |  |  |  |  |  |  |
| 118 SPRINGER 115. 2L 0.444@ 94.6 0.444@ 94.6 0.269@ 101.7 1.156@ 96.2 0.181@ -95.9 0.181@ -95.9      |  |  |  |  |  |  |  |  |  |  |  |
| 66 VALENCIA 115. 1L 0.613@ 105.9 0.613@ 105.9 0.718@ 102.6 1.944@ 104.7 0.112@ 84.0 0.112@ 83.9      |  |  |  |  |  |  |  |  |  |  |  |
| 118 SPRINGER 115. 1L 0.402@ 102.0 0.402@ 102.0 0.221@ 106.7 1.023@ 103.0 0.183@ -83.7 0.183@ -83.8   |  |  |  |  |  |  |  |  |  |  |  |
| CURRENT TO FAULT (PU) > 1.454@ -78.6 1.454@ -78.6 1.454@ -78.6 4.362@ -78.6 0.000@ 0.0 0.000@ 0.0    |  |  |  |  |  |  |  |  |  |  |  |
| THEVENIN IMPEDANCE (PU) > 0.2035@ 76.6 0.20345@ 76.6 0.28138@ 81.6                                   |  |  |  |  |  |  |  |  |  |  |  |
| -----                                                                                                |  |  |  |  |  |  |  |  |  |  |  |
| EQUIVALENT IMPEDANCE OF MOV-PROTECTED SERIES CAPACITORS THAT FIRED (PU):                             |  |  |  |  |  |  |  |  |  |  |  |
| CAP FW 345.000kV - RIO_PUERCO 345.000kV PHASE A PHASE B PHASE C                                      |  |  |  |  |  |  |  |  |  |  |  |
| 0.000 + j-0.027 0.000 + j-0.027 0.000 + j-0.027                                                      |  |  |  |  |  |  |  |  |  |  |  |
| CAP WW 345.000kV - RIO_PUERCO 345.000kV 0.000 + j-0.027 0.000 + j-0.027 0.000 + j-0.027              |  |  |  |  |  |  |  |  |  |  |  |
| OJO 345.000kV - OJO CAP 345.000kV 0.000 + j-0.037 0.000 + j-0.037 0.000 + j-0.037                    |  |  |  |  |  |  |  |  |  |  |  |
| -----                                                                                                |  |  |  |  |  |  |  |  |  |  |  |
| =====                                                                                                |  |  |  |  |  |  |  |  |  |  |  |
| =====                                                                                                |  |  |  |  |  |  |  |  |  |  |  |



## Appendix E – Historical Walsenburg – Gladstone 230 kV flows

Confidential: Sean Black (ID 68709) | sblack2@ameren.com | Ameren on 2019-03-05

## Walsenburg - Gladstone 230 kV Line Flows



Confidential: Sean Black (ID 68709) | sblack2@ameren.com | Ameren on 2019-03-05